



Post Fukushima

National Action Plan (NAcP)

on
Strengthening Nuclear Safety of Nuclear Facilities
in the Czech Republic



State Office for Nuclear Safety
December 2012

Content

| | |
|---|----|
| 1. Introduction | 5 |
| 2. European level recommendations | 7 |
| PART I | 8 |
| 3. Other topics | 8 |
| 3.1 Topic I – Natural hazards | 8 |
| 3.1.1 Hazard Frequency | 8 |
| 3.1.2 Secondary Effects of Earthquakes | 10 |
| 3.1.3 Protected Volume Approach | 11 |
| 3.1.4 Early Warning Notifications | 12 |
| 3.1.5 Seismic Monitoring | 12 |
| 3.1.6 Qualified Walkdowns | 13 |
| 3.1.7 Flooding Margin Assessments | 13 |
| 3.1.8 External Hazard Margins | 15 |
| 3.2 Topic 2 - Loss of safety systems | 17 |
| 3.2.1 Alternate Cooling and Heat Sink | 18 |
| 3.2.2 AC Power Supplies | 22 |
| 3.2.3 DC Power Supplies | 23 |
| 3.2.4 Operational and Preparatory Actions | 25 |
| 3.2.5 Instrumentation and Monitoring | 25 |
| 3.2.6 Shutdown Improvements | 26 |
| 3.2.7 Reactor Coolant Pump Seals | 26 |
| 3.2.8 Ventilation | 26 |
| 3.2.9 Main and Emergency Control Rooms | 27 |
| 3.2.10 Spent Fuel Pool | 28 |
| 3.2.11 Separation and Independence | 29 |
| 3.2.12 Flow Path and Access Availability | 30 |
| 3.2.13 Mobile Devices | 31 |
| 3.2.14 Bunkered/Hardened Systems | 32 |
| 3.2.15 Multiple Accidents | 33 |
| 3.2.16 Equipment Inspection and Training Programs | 35 |
| 3.2.17 Further Studies to Address Uncertainties | 36 |
| 3.3 Topic 3 - Severe accident management | 39 |
| 3.3.1 WENRA Reference Levels | 39 |
| 3.3.2 SAM Hardware Provisions | 39 |
| 3.3.3 Review of SAM Provisions Following Severe External Events | 42 |
| 3.3.4 Enhancement of Severe Accident Management Guidelines (SAMG) | 43 |
| 3.3.5 SAMG Validation | 44 |
| 3.3.6 SAM Exercises | 45 |
| 3.3.7 SAM Training | 45 |
| 3.3.8 Extension of SAMGs to All Plant States | 46 |
| 3.3.9 Improved Communications | 47 |
| 3.3.10 Presence of Hydrogen in Unexpected Places | 49 |
| 3.3.11 Large Volumes of Contaminated Water | 49 |
| 3.3.12 Radiation Protection | 50 |
| 3.3.13 On Site Emergency Centre | 51 |
| 3.3.14 Support to Local Operators | 52 |
| 3.3.15 Level 2 Probabilistic Safety Assessments (PSAs) | 52 |
| 3.3.16 Severe Accident Studies | 53 |

| | |
|---|----|
| PART II | 54 |
| 4. Issues from CNS EOM Group discussions | 54 |
| 4.1 Topic 4 - National organisations | 54 |
| 4.2 Topic 5 - Emergency Preparedness and Response | 56 |
| 4.3 Topic 6 - International Cooperation..... | 57 |
| Part III..... | 59 |
| 5. Cross-cutting issues | 59 |
| PART IV | 60 |
| 6. Implementation Activities - Actions..... | 60 |
| 7. Conclusions | 68 |
| References..... | 68 |

1. Introduction

Post Fukushima National Action Plan (NACP) on Strengthening Nuclear Safety of Nuclear Facilities in the Czech Republic follows the National Report on „Stress Tests“ of Dukovany NPP and Temelín NPP, Czech Republic [1], prepared under the initiative of the European Commission in response to the Fukushima nuclear power plant accident.

In accordance with the specifications elaborated by a group of European Nuclear Regulators ENSREG the national stress tests report analyzed in detail the safety aspects of Dukovany and Temelin NPPs in terms of extreme external conditions, particularly their robustness against beyond design basis earthquakes, floods and extreme weather conditions leading to loss of ultimate heat sink, complete loss of electrical power (black out) or a combination thereof. The aim of the stress tests was to assess the resistance of existing nuclear power plants to these extreme loads, to assess time reserves to cliff edge moments of irreversible damage of the reactor core and to propose measures to strengthen their overall robustness in similar extreme situations.

National stress tests report has resulted in the conclusion that the design basis, which was used in the design of both nuclear power plants is in accordance with the valid nuclear legislation of the Czech Republic and that they both have sufficient reserves to the analyzed very unlikely extreme events. Detailed analyses of the behaviour of nuclear power plants in these extreme conditions allowed to propose a number of specific technical and administrative measures to further enhance their robustness and delaying the onset of irreversible damage of the nuclear fuel and barriers preventing release of fission products into the plant and then into the environment.

National Report of the Czech Republic along with national reports of other countries were subject to a detailed assessment by an independent group of international experts, initially in topically oriented peer review organized by the European Commission and the ENSREG in February 2012 in Luxembourg. The results of this topical peer review were summarized in two forms: first in a summary report generalizing conclusions and recommendations based on all national reports [2], secondly, in national evaluation peer review reports, which were a basis for subsequent evaluation missions (so-called "country visits") associated with visit of a selected nuclear power plant. In the case of the Czech Republic it was the Dukovany NPP. Conclusions of this evaluation were summarized in the final "Peer Review Country Report" [3], containing in addition to the general summary evaluation a list of recommendations for further improvement of nuclear safety in the Czech Republic, both of general nature and specific for Dukovany and Temelín NPPs. This assessment by independent international experts confirmed the general conclusions of the National Report on the compliance of design bases of the Czech nuclear power plants with applicable national laws and international practices. Final review of stress tests of the Czech NPPs by ENSREG group ended with a visit to the Temelín NPP in September 2012, the conclusions of which were summarized in the report [4].

National stress tests report of the Czech nuclear power plants was in a condensed form [5] also presented to the Second Extraordinary Meeting of the Parties to the Convention on Nuclear Safety, which took place on 27 - 31 August 2012 at the International Atomic Energy Agency (IAEA). Conclusions of this meeting, summarized in a document [6] became, like the

conclusions of the evaluation of stress tests carried out within the group ENSREG, a source of ideas for further increasing the level of nuclear safety of Contracting Parties to the Convention, including the Czech Republic.

Recommendations from the review processes within the ENSREG Group and the Extraordinary meeting of the Contracting Parties to the Convention on Nuclear Safety, along with opportunities to enhance robustness of Dukovany and Temelín NPPs identified in the National Stress Tests Report form a set of measures, which represent the basis of the present National Action Plan (NACP) on Strengthening Nuclear Safety of Nuclear Facilities in the Czech Republic

National Action Plan on Strengthening Nuclear Safety of Nuclear Facilities in the Czech Republic contains a compilation of all the major conclusions and recommendations contained in the National Stress Tests Report on nuclear power plants of the Czech Republic [1], reports from the peer review process by the ENSREG group [2,3,4,], including the Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the Convention on Nuclear safety [6]. The National Action Plan is structured, in accordance with the structure suggested by ENSREG [7], into four parts. Part I is devoted to the issues of external hazards (earthquakes, floods, extreme weather conditions), the loss of ultimate heat sink and complete loss of electrical power, eventually their combination. Part II deals with the national organization, the organization of emergency preparedness and emergency response, and international cooperation, as were evaluated at an extraordinary meeting of the Convention on Nuclear Safety. Part III is devoted to the cross/cutting issues. The focus of the Action Plan - Part IV - contains the list of measures aimed in implementing all the recommendations contained in parts I - III. The set of these measures is the sum of corrective actions identified in the Periodic safety review of Dukovany NPP and Temelín NPP after 20, respectively 10 years of operation, safety findings by the IAEA missions, findings identified within the project LTO EDU and last but not least, the findings identified in the stress tests after the Fukushima nuclear power plant disaster.

Proposed measures relating to Dukovany NPP and Temelín NPP will be implemented by the licensee ČEZ, a.s.. Measures of general nature, such as the amendment of the nuclear legislation, off-site emergency preparedness, international cooperation, etc. will be implemented by the state administration, especially SÚJB and other ministries.

National Action Plan on Strengthening Nuclear Safety of Nuclear Facilities in the Czech Republic is a living document which will be regularly reviewed and based on new knowledge continuously updated.

2. European level recommendations

| No. | Recommendations | Activity/Action | Topic |
|-----|---|-----------------|---------|
| | Recommendations from ENSREG ,, Compilation of recommendations and suggestions,, | | |
| 1 | The peer review Board recommends that WENRA, involving the best available expertise from Europe, develop guidance on natural hazards assessments, including earthquake, flooding and extreme weather conditions, as well as corresponding guidance on the assessment of margins beyond the design basis and cliff-edge effects. | | general |
| 2 | The peer review Board recommends that ENSREG underline the importance of periodic safety review. In particular, ENSREG should highlight the necessity to reevaluate natural hazards and relevant plant provisions as often as appropriate but at least every 10 years. External hazards and their influence on the licensing basis should be reassessed periodically using state-of-the-art data and methods. PSR was identified as one good tool. | | general |
| 3 | Urgent implementation of the recognised measures to protect containment integrity is a finding of the peer review that national regulators should consider. | | general |
| 4 | Necessary implementation of measures allowing prevention of accidents and limitation of their consequences in case of extreme natural hazards is a finding of the peer review that national regulators should consider. | | general |
| 5 | Deterministic methods should form the basis for hazard assessment. Probabilistic methods, including probabilistic safety assessment (PSA), are useful to supplement the deterministic methods. | | general |

PART I

3. Other topics

| 3.1 Topic I – Natural hazards | | | |
|--|---|----------------------------|--------------|
| 3.1.1 Hazard Frequency | | | |
| No. | Recommendations | Activity Action No. | Topic |
| Hazard Frequency The use a return frequency of 10E-4 per annum (0.1g minimum peak ground acceleration for earthquakes) for plant reviews/back-fitting with respect to external hazards safety cases. | | 1, 2, 3 | |
| | | | |
| 3.1.1.1 | Recommendations from National Stress test Report | | |
| 3.1.1.1.1 | NPP Dukovany: To complete the project of Dukovany NPP seismic upgrading. (tab.10) | | |
| 3.1.1.1.2 | NPP Dukovany: Control and ensuring of non-seismic equipment anchoring (tab.10) | | |
| 3.1.1.1.3 | NPP Dukovany: To work out earthquake operating regulations (tab.10) | | |
| 3.1.1.1.4 | NPP Dukovany: EDMG instructions for use of alternative means (tab.10) | | |
| 3.1.1.1.5 | NPP Dukovany: To ensure working of emergency response units in case of unavailability of ECC (tab.10) | | |
| 3.1.1.1.6 | NPP Dukovany: Seismic resistance of LFRU building (tab.10) | | |

| | | | |
|------------|---|--|--|
| 3.1.1.1.7 | NPP Dukovany: Alternative means of communications after a seismic event (tab.10) | | |
| 3.1.1.1.8 | NPP Dukovany: Analysis regarding threat to shelters on a seismic event (tab.10) | | |
| 3.1.1.1.9 | NPP Dukovany: Ensuring of sufficient amount of staff after a seismic event (tab.10) | | |
| 3.1.1.1.10 | NPP Dukovany: Access to buildings, availability of machinery (tab.10) | | |
| 3.1.1.1.11 | NPP Temelin: Alternative refuelling diesel using tank trucks for long-term operation of the DG (tab.30) | | |
| 3.1.1.1.12 | NPP Temelin: EDMG manuals for using alternative means. (tab.30) | | |
| 3.1.1.1.13 | NPP Temelin: OER (organization of emergency response) ability outside the ECC (emergency control centre) (tab.30) | | |
| 3.1.1.1.14 | NPP Temelin: Resilience of the LFRU (local fire rescue unit) to seismicity (tab.30) | | |
| 3.1.1.1.15 | NPP Temelin: Alternative means of communication after a seismic event (tab.30) | | |
| 3.1.1.1.16 | NPP Temelin: Analysis of the threat to the shelters in case of a seismic event (tab.30) | | |
| 3.1.1.1.17 | NPP Temelin: Security of the staff after a seismic event (tab.30) | | |
| 3.1.1.1.18 | NPP Temelin: Access to buildings, accessibility for heavy machinery (tab.30) | | |
| 3.1.1.2 | Recommendations from ENSREG Country Peer Review | | |

| | | | |
|---|--|----------|-----------------|
| 3.1.1.2.1 | <p>NPP Dukovany: During the plant visit it was explained that SSCs of safety classified systems reach resistance values between 0,11g and 0,169g. The upper resistance limits for circulation cooling water is given as 0.112g, based on the capability of the cooling towers. It is recommended that SUJB should consider ensuring enhanced capability for this function is developed. (page 7)</p> | | |
| 3.1.1.2.2 | <p>NPP Dukovany: The upgrade program for Dukovany NPP is scheduled to be completed in 2015. It is recommended that SUJB should continue to monitor the ongoing earthquake resistance qualifications and reinforcements for the Dukovany NPP to ensure that all the safety related SSCs of the plant are resistant for at least 0.1 g PGA. It is also recommended that the proposed reinforcement should continue to be monitored by the national regulator. (page 8).</p> | | |
| 3.1.1.2.3 | <p>NPP Dukovany: It is recommended that SUJB should consider how to monitor resolution of:</p> <ul style="list-style-type: none"> • actions to increase the plant's capabilities to cope with the indirect effects of an earthquake and other external events • low seismic margins for cooling towers serving as heat sink for the ESW • low seismic capability for fire brigade building. (page 8) | | |
| 3.1.1.3 | Luxembourg general peer review report | | |
| 3.1.1.3.1 | Driving all plant reviews/back-fitting with respect to external hazards safety cases to the 10 ⁻⁴ per annum/0.1g minimum peak ground acceleration. (§5.3.1) | | |
| 3.1.1.4 | ENSREG - Follow - up fact finding site visit NPP Temelin | | |
| 3.1.1.4.1 | Seismically qualifying the fire brigade building (page 3.) | | |
| 3.1.2 Secondary Effects of Earthquakes | | | |
| Secondary Effects of Earthquakes The possible secondary effects of seismic events, such as flood or fire arising as a result of the event, in future assessments. | | 4 | natural hazards |

| | | | |
|---|---|--------------|-----------------|
| | | | |
| 3.1.2.1 | Recommendations from National Stress test Report | | |
| 3.1.2.1.1 | NPP Dukovany: Seismic PSA (tab.10) | | |
| 3.1.2.2 | Recommendations from ENSERG Country Peer Review | | |
| 3.1.2.2.1 | NPP Dukovany: It is recommended that SUJB should consider how to monitor resolution of: • actions to increase the plant’s capabilities to cope with the indirect effects of an earthquake and other external events (page 8) | | |
| 3.1.2.3 | Luxembourg general peer review report | | |
| 3.1.2.3.1 | Clarifying requirements for the approach to the secondary effects of seismic events, such as flood or fire arising as a result of the event, in future assessments. (§5.3.5) | | |
| | | | |
| 3.1.3 Protected Volume Approach | | | |
| Protected Volume Approach The use a protected volume approach to demonstrate flood protection for identified rooms or spaces. | | 4, 70 | natural hazards |
| | | | |
| 3.1.3.1 | Luxembourg general peer review report | | |
| 3.1.3.1.1 | Clarifying requirements for the approach to the secondary effects of seismic events, such as flood or fire arising as a result of the event, in future assessments. (§5.3.5) Temelin and Dukovany sites are not endangered by natural or specific floods. However, all buildings are designed with the respect to withstand extreme rainwater. | | |
| 3.1.3.1.2 | That the protected volume approach is an effective way of demonstrating flood protection for identified rooms or spaces. (§ 5.3.6) All buildings were inspected and additional measures against extreme rainwater in selected buildings have been implemented. | | |
| | | | |

| | | | |
|--|--|----------|-----------------|
| 3.1.4 Early Warning Notifications | | | |
| Early Warning Notifications The implementation of advanced warning systems for deteriorating weather, as well as the provision of appropriate procedures to be followed by operators when warnings are made. | | 5 | natural hazards |
| | | | |
| 3.1.4.1 | Luxembourg general peer review report | | |
| 3.1.4.1.1 | That some countries refer to weather alert systems. Advance warning of deteriorating weather is often available in sufficient time to provide the operators with useful advice and national regulators should ensure that appropriate communications and procedures are developed by all operators.(§ 5.3.11) | | |
| | | | |
| 3.1.5 Seismic Monitoring | | | |
| Seismic Monitoring The installation of seismic monitoring systems with related procedures and training. | | 6 | natural hazards |
| | | | |
| 3.1.5.1 | Recommendations from ENSREG Country Peer Review | | |
| 3.1.5.1.1 | NPP Dukovany: During the PSR process a re-evaluation against 0,1g PGA for Dukovany NPP, in line with IAEA guidance has been introduced. During the country visit it was explained that work has been carried out to evaluate the seismic hazard using modern methods taking account of recent paleoseismological and geodetic data. This SHA is still to be validated and it is recommended that SUJB considers the implications during the PSR process. (page 8.) | | |
| 3.1.5.2 | Luxembourg general peer review report | | |
| 3.1.5.2.1 | Installation of seismic monitoring systems and development of associated procedures and training for those NPPs that currently do not have such systems. (§5.3.10) Internal seismic monitoring system is implemented at Temelin NPP. | | |
| | | | |

| 3.1.6 Qualified Walkdowns | | | |
|--|---|------------------|-----------------|
| Qualified Walkdowns The development of standards to address qualified plant walkdowns with regard to earthquake, flooding and extreme weather – to provide a more systematic search for non-conformities and correct them (e.g. appropriate storage of equipment, particularly for temporary and mobile plant and tools used to mitigate beyond design basis (BDB) external events). | | 7, 8 | natural hazards |
| | | | |
| 3.1.6.1 | Luxembourg general peer review report | | |
| 3.1.6.1.1 | How best to ensure that specific operational requirements of external events safety cases are adequately maintained. Regulators and operators should consider developing standards to address qualified plant walkdowns with regards to earthquake, flooding and extreme weather – to provide a more systematic search for non-conformities and correct them (e.g. appropriate storage of equipment, particularly for temporary and mobile plant and tools used to mitigate BDB external events). This plant-based activity would benefit from clear labelling of qualified equipment. (§ 5.3.7) Extraordinary inspections (during May, 2011) of plant resistance against internal and external floods were conducted. No significant discrepancy of current status with design requirements have been identified at Temelin NPP and only minor discrepancies of current status with design requirements have been identified at Dukovany NPP that were immediately corrected. | | |
| | | | |
| 3.1.7 Flooding Margin Assessments | | | |
| Flooding Margin Assessments The analysis of incrementally increased flood levels beyond the design basis and identification of potential improvements, as required by the initial ENSREG specification for the stress tests. | | 9, 10, 11 | natural hazards |
| | | | |
| 3.1.7.1 | Recommendations from National Stress test Report | | |
| 3.1.7.1.1 | NPP Dukovany: EDMG instructions for use of alternative means (tab.11) | | |
| 3.1.7.1.2 | NPP Dukovany: Analysis regarding threat to shelters in the case of floods (tab.11) | | |

| | | | |
|-----------|---|--|--|
| 3.1.7.1.3 | NPP Temelin: Increasing the resilience of the DG in case of external flooding (tab.31) | | |
| 3.1.7.1.4 | NPP Temelin: Ability of the OER to function via the ECC (tab.31) | | |
| 3.1.7.1.5 | NPP Temelin: EDMG manuals for using alternative means (tab.31) | | |
| 3.1.7.1.6 | NPP Temelin: Analysis of the threat to the shelters in case of floods (tab.31) | | |
| 3.1.7.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.1.7.2.1 | NPP Temelin: Increasing the protection of the diesel fuel pumps against the effects of flooding and also an alternative shelter is to be set up for the emergency response organization when the dedicated emergency response centre is damaged due to some external hazard. (page 10) | | |
| 3.1.7.2.2 | NPP Temelin: Convincing information is provided that the flooding from external water courses is “inherently ruled out” and the possible maximum flooding due to extreme rainfall is limited due to the morphological characteristics of the sites. At the same time there is a proposed measure for the Temelin site that the resilience of the emergency diesel generators should be increased, with a reference to the latest PSR. (page 10) | | |
| 3.1.7.2.3 | For both NPPs: The main requirement is that the SSCs necessary for safe shutdown of the plant need to remain operational after any possible flood situation. (page 9.) | | |
| 3.1.7.2.4 | For both NPPs: Some modifications to emergency procedures and analyses regarding the usability of the shelters under flooding conditions are foreseen. (page 10) | | |
| 3.1.7.3 | Luxembourg general peer review report | | |

| | | | |
|--|---|-----------|-----------------|
| 3.1.7.3.1 | That in all countries that have not considered incrementally increased flood levels and associated potential improvements they should consider requiring the operators to do so. When carried out at the right level, the exercise is practicable and can easily provide valuable insight into effective and realistic improvements. (§ 5.3.2) | | |
| 3.1.7.4 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.1.7.4.1 | Increasing the protection of the diesel fuel tanks against the effects of flooding (with a reference to the latest PSR) (page 3.) | | |
| 3.1.7.4.2 | Increase resistance against rainfall of several buildings (DG's building and emergency shelter) (page 3.) | | |
| 3.1.7.4.3 | Setting up an alternative shelter for the emergency response organization (e.g. when the dedicated emergency response centre is damaged due to some external hazard – like flooding) (page 3.) | | |
| 3.1.8 External Hazard Margins | | | |
| External Hazard Margins In conjunction with recommendation 1 and 17, the formal assessment of margins for all external hazards including, seismic, flooding and severe weather, and identification of potential improvements. Licensing basis protection against external hazards (e.g. flood seals and seismic supports) should be verified to be effective. Margin assessments should be based on periodic re-evaluation of licensing basis for external events considering possible cliff-edge effects and grace periods. | | 12 | natural hazards |
| 3.1.8.1 | Recommendations from National Stress test Report | | |
| 3.1.8.1.1 | NPP Dukovany: To implement measures for diversion means of the ultimate heat sink (to CT). (tab.15) | | |
| 3.1.8.1.2 | NPP Dukovany: To work out operating regulations for extreme events (wind, temperature, snow) (tab.15) | | |
| 3.1.8.1.3 | NPP Dukovany: EDMG instructions for use of alternative means (tab.15) | | |

| | | | |
|-----------|--|--|--|
| 3.1.8.1.4 | NPP Dukovany: Ensuring of sufficient number of staff after extreme events (tab.15) | | |
| 3.1.8.1.5 | NPP Dukovany: Resistance of civil structures (LFRU, CPS, MPU etc.) to extreme conditions (tab.15) | | |
| 3.1.8.1.6 | NPP Dukovany: To work out methods of evaluation of external effects, verification of analyses performed, possible technical measures (tab.15) | | |
| 3.1.8.1.7 | NPP Temelin: Alternative supply of diesel fuel from the tank for long-term operation of the DG. (tab.33) | | |
| 3.1.8.1.8 | NPP Temelin: Ensuring safety and operational staff in case of extreme events (tab.33) | | |
| 3.1.8.1.9 | NPP Temelin: Executing methodology for assessing external effects, verification of analyses carried out, possible technical measures (tab.33) | | |
| 3.1.8.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.1.8.2.1 | NPP Dukovany: There is a reference to the Dukovany PSR in relation to ensuring separation of safety systems from systems for normal operation used for ultimate heat sink because of the inadequate capability of the cooling towers in regard to extreme wind. Possibilities include using separate cooling towers or sprinkler pools for ESW heat sink. It is recommended that the SUJB considers how to ensure that this issue is effectively resolved and appropriate improvements incorporated. (page 11) | | |

| | | | |
|---|--|--|--|
| 3.1.8.2.2 | <p>For both NPPs:</p> <p>In the stress test process it has been identified that the procedures for special handling of weather related threats need to be elaborated and some specific additions might be necessary to the emergency management procedures. The organizational arrangements to ensure the necessary staff in case of lasting extreme weather conditions have to be elaborated. The considerations for extreme low temperatures may be too simple, not taking into account the realistic related effects, e.g. station black-out. Some refined further analyses and verification of current analyses are judged to be necessary. The elaboration of diverse connection to the ultimate heat sink and the load analyses of specific civil structures are already in progress and it is recommended that the SUJB should ensure that the question of diverse ultimate heat sink is resolved effectively. (page 11)</p> | | |
| 3.1.8.3 | Luxembourg general peer review report | | |
| 3.1.8.3.1 | Strengthening the PSR process by encouraging a more consistent approach to the determination of margins for external events, including external event PSAs (including seismic) and regular reviews of the design and beyond design hazards. (§ 5.3.3) | | |
| 3.1.8.3.2 | Those with regard to hazard definition, techniques and data are still developing. WENRA, involving the best available expertise from Europe, should develop guidance on natural hazards assessments, including earthquake, flooding and extreme weather conditions, as well as corresponding guidance on the assessment of margins beyond the design basis and cliff edge effects. (§5.3.4) | | |
| 3.1.8.4 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.1.8.4.1 | Elaboration of procedures for special handling of weather related threats with some specific additions to the emergency management procedures. (e.g. organizational arrangements to ensure the necessary staff in case of lasting extreme weather conditions) (page 3.) | | |
| 3.1.8.5 | Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS | | |
| 3.1.8.5.1 | Re-evaluating the hazards posed by external events, such as earthquakes, flood and extreme weather conditions, for each nuclear power plant site through targeted reassessment of safety. (page 5.) | | |
| | | | |
| 3.2 Topic 2 - Loss of safety systems | | | |

| 3.2.1 Alternate Cooling and Heat Sink | | | |
|---|--|-------------------------------|---------------|
| Alternate Cooling and Heat Sink The provision of alternative means of cooling including alternate heat sinks. | | 13, 14, 15, 16, 17, 73 | design issues |
| | | | |
| 3.2.1.1 | Recommendations from National Stress test Report | | |
| 3.2.1.1.1 | NPP Dukovany: Ensuring additional source for adding water into SG. (tab.17) | | |
| 3.2.1.1.2 | NPP Dukovany: Analysis of possibility of alternative adding of water into the reactor by pump and new pipeline (tab.17) | | |
| 3.2.1.1.3 | NPP Dukovany: Implementation of measures for diversified means of the ultimate heat sink (to CT) (tab.17) | | |
| 3.2.1.1.4 | NPP Dukovany: Preparation of the procedure for the loss of UHS and ESW systems on all 4 units (tab.17) | | |
| 3.2.1.1.5 | NPP Dukovany: Completion of the existing regulations with the procedure for filling SG of all four units by fire extinguishing technology (tab.17) | | |
| 3.2.1.1.6 | NPP Dukovany: The existing regulations prefer the way of filling the open reactor and SFSP with self-gravitation from XL trays (tab.17) | | |
| 3.2.1.1.7 | NPP Dukovany: The collection of cooling from SFSP by adding coolant and accumulation in TH tanks (tab.17) | | |
| 3.2.1.1.8 | NPP Dukovany: EDMG manuals for the use of alternative means (tab.17) | | |
| 3.2.1.1.9 | NPP Dukovany: Ensuring additional supply source for systems SPS I. category and selected consumer appliances SPS II. category. (tab.18) | | |

| | | | |
|------------|---|--|--|
| 3.2.1.1.10 | NPP Dukovany: Production of the procedure for restoration of SBO supply for all units (tab.18) | | |
| 3.2.1.1.11 | NPP Temelin: Alternative water supply for SG/SFSP/I.C (in case of I.C leakage). (tab.34) | | |
| 3.2.1.1.12 | NPP Temelin: Analysis of heat transfer from the I&C after losing the ESW (tab.34) | | |
| 3.2.1.1.13 | NPP Temelin: Procedure for restoring the power supply after an SBO in all units (tab.34) | | |
| 3.2.1.1.14 | NPP Temelin: EDMG manuals for using alternative means (tab.34) | | |
| 3.2.1.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.1.2.1 | NPP Dukovany There is a reference to the Dukovany PSR in relation to ensuring separation of safety systems from systems for normal operation used for ultimate heat sink because of the inadequate capability of the cooling towers in regard to extreme wind. Possibilities include using separate cooling towers or sprinkler pools for ESW heat sink. It is recommended that the SUJB considers how to ensure that this issue is effectively resolved and appropriate improvements incorporated. (page 11.) | | |
| 3.2.1.2.2 | NPP Dukovany: In Dukovany NPP there are 4 wet cooling towers for twin units, which serve as heat sink for service water and also for essential service water (TVD) systems. Cooling towers are not qualified as safety components. This issue was recognized during the last periodic safety review in 2009, and is being addressed by the project "Separation of safety systems from operational systems" (No. 5983). As it was discussed during the country visit, this safety improvement project is currently in design phase; the hardware modification is scheduled from 2015 to 2017. It is recommended, that the regulator considers how to ensure this is resolved effectively. (page 15.) | | |

| | | | |
|-----------|--|--|--|
| 3.2.1.2.3 | <p>NPP Dukovany:</p> <ul style="list-style-type: none"> • Specific possible safety improvements for Dukovany NPP related to the loss of UHS: Implement diverse (to the cooling tower) UHS means • Develop a procedure for the loss of UHS and ESW systems in all 4 units • Develop a procedure for the refilling of steam generators using fire fighting equipments • Filling an open reactor and spent fuel pool (SFP) by gravity drainage from bubbler trays • Removal of heat from the coolant in the SFP by means of coolant replenishment and its accumulation in emergency cooling water tanks (TH-system) • Extensive damage mitigation guidelines for the use of alternative means (page 17.) | | |
| 3.2.1.2.4 | <p>NPP Dukovany:</p> <p>In general there is redundancy and diversity in the electric and cooling capabilities to ensure safety functions, however additional alternate heat sink has not be implemented in Dukovany NPP. Besides that there are plans to increase system robustness to cope with SBO and LUHS. SUJB should follow the diversification of ultimate heat sink in Dukovany and the application of means and procedures to improve battery discharge time and makeup of steam generators. (page 17.)</p> | | |
| 3.2.1.2.5 | <p>NPP Temelin:</p> <p>In Temelin NPP enough fire trucks are present, however no water connection points are available on relevant systems of the units. Safety improvement measure was decided by the licensee to resolve this issue. It was clarified during the country visit that the first phase of system modification will be realized in 2012, and the full implementation is planned in 2013. SUJB should consider to follow up the implementation (page 16)</p> | | |
| 3.2.1.2.6 | <p>NPP Temelin:</p> <ul style="list-style-type: none"> • Specific possible safety improvements for Temelin NPP related to the loss of UHS: • Install new hook up points for fire trucks • Develop a procedure for the loss of UHS and ESW systems in both units • Extensive damage mitigation guidelines for the use of alternative means • Alternative replenishment of water to steam generator/SFP/primary circuit (with unsealed primary circuit) • Analysis of heat removal from I&C systems following a loss of ESW (page 17.) | | |

| | | | |
|-----------|---|--|--|
| 3.2.1.2.7 | <p>For both NPPs: In the stress test process it has been identified that the procedures for special handling of weather related threats need to be elaborated and some specific additions might be necessary to the emergency management procedures. The organizational arrangements to ensure the necessary staff in case of lasting extreme weather conditions have to be elaborated. The considerations for extreme low temperatures may be too simple, not taking into account the realistic related effects, e.g. station black-out. Some refined further analyses and verification of current analyses are judged to be necessary. The elaboration of diverse connection to the ultimate heat sink and the load analyses of specific civil structures are already in progress and it is recommended that the SUJB should ensure that the question of diverse ultimate heat sink is resolved effectively. (page 11.)</p> | | |
| 3.2.1.2.8 | <p>For both NPPs: It is recommended, that the SUJB consider how to monitor the licensee in respect:</p> <ul style="list-style-type: none"> • to ensure that the new safety related equipment has beyond design basis capability for hazards. • to increase the plant robustness by implementation of alternative means for AC power supply for core cooling and heat removal • to improve the battery depletion time and implement battery recharging • to provide additional fire truck (Dukovany NPP) • to install hook up points for steam generator water make-up at Temelin NPP (page 17.) | | |
| 3.2.1.3 | Luxembourg general peer review report | | |
| 3.2.1.3.1 | Using alternative means of cooling including alternate heat sinks. SG gravity feeding, or using other sources of water, supply from stored condenser cooling water, alternate tanks or wells on the site, or water sources in the vicinity (reservoir, lakes, etc) is an additional way of enabling core cooling and prevention of fuel degradation. Some plants identified possible actions, including additional analysis that might be needed. (§ 6.3.2) | | |
| 3.2.1.4 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.2.1.4.1 | Installing new hook up points for fire trucks (page 3.) | | |
| | | | |

| 3.2.2 AC Power Supplies | | | |
|---|---|-------------------|---------------|
| AC Power Supplies The enhancement of the on-site and off-site power supplies. | | 18, 19, 74 | design issues |
| | | | |
| 3.2.2.1 | Recommendations from National Stress test Report | | |
| 3.2.2.1.1 | NPP Dukovany: Ensuring additional supply source for systems SPS I. category and selected consumer appliances SPS II. category. (tab.16) | | |
| 3.2.2.1.2 | NPP Dukovany: Production of the procedure for restoration of SBO supply for all units (tab.16) | | |
| 3.2.2.1.3 | NPP Dukovany: Production of the procedure for filling of SG of all four units by fire extinguishing technology (tab.16) | | |
| 3.2.2.1.4 | NPP Dukovany: Ensuring alternative source of electricity for safe places and telephone exchanges (tab.16) | | |
| 3.2.2.1.5 | NPP Dukovany: Ensuring alternative source of electricity for the TSPP supply (tab.16) | | |
| 3.2.2.1.6 | NPP Dukovany: Ensuring sufficient personnel during long-term SBO (tab.16) | | |
| 3.2.2.1.7 | NPP Dukovany: Ensuring the functioning of emergency response elements in the case of non-accessibility of ECC (tab.16) | | |
| 3.2.2.1.8 | NPP Temelin: Securing a sufficient number of staff in case of a long-term SBO (tab.34) | | |
| 3.2.2.1.9 | NPP Temelin: Analyses of the possibility of shift staff in case of an SBO in both units (tab 34.) | | |

| | | | |
|--------------------------------|---|-------------------|---------------|
| 3.2.2.1.10 | NPP Temelin: Alternative sources and means of communication after a seismic event (tab. 34) | | |
| 3.2.2.1.11 | NPP Temelin: Executing procedures for the operation of units in case of a long-term power supply from emergency sources (tab.34) | | |
| 3.2.2.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.2.2.1 | For both NPPs: It is recommended, that the SUJB consider how to monitor the licensee in respect: • to increase the plant robustness by implementation of alternative means for AC power supply for core cooling and heat removal to improve the battery depletion time and implement battery recharging. (page 17.) | | |
| 3.2.2.3 | Luxembourg general peer review report | | |
| 3.2.2.3.1 | Backup (SBO) DG installation (page 3.) | | |
| | | | |
| 3.2.3 DC Power Supplies | | | |
| | DC Power Supplies The enhancement of the DC power supply. | 20, 21, 75 | design issues |
| 3.2.3.1 | Recommendations from National Stress test Report | | |
| 3.2.3.1.1 | NPP Dukovany: Analysis of the discharging time of accumulator batteries for the unit for releasing the load, filling OIs , changing the connection and operation of emergency lighting (including replacement of light bulbs by energy saving lamps) (tab.16) | | |
| 3.2.3.1.2 | NPP Temelin: Alternative source for recharging accumulator batteries and supplying selected appliances (tab.34) | | |
| 3.2.3.1.3 | NPP Temelin: Using the safety DG of the other unit in case of an SBO (tab.34) | | |

| | | | |
|-----------|--|--|--|
| 3.2.3.1.4 | NPP Temelin: Analysis of the discharging period of the accumulator batteries in case of a controlled reduction of the load, details on procedures (including replacement of light bulbs by energy saving lamps) (tab.34) | | |
| 3.2.3.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.3.2.1 | NPP Dukovany: The capacity of the accumulator battery sets of Dukovany uninterruptable power supply SZN1, 2 and 3 is 1500 Ah. According to the design, the discharge time of accumulator batteries with the maximum conservative load is at least 2 hours. Procedures have been developed to reduce the less important loads and saving of DC capacity. The real depletion time may be much longer than two hours (6 to 8 hours). Based on the fact that battery depletion is an important cliff edge effect, further improvements are under consideration. It is recommended, that the regulator considers how to ensure this is resolved effectively. (page 15.) | | |
| 3.2.3.2.2 | NPP Temelin: Temelin NPP is equipped with 3x1600 Ah batteries for power supply of safety systems and 2x2400 Ah batteries for safety related consumers. The discharge time for these batteries is also at least 2 hours. Currently, recharging of the accumulator batteries during SBO is not provided. If the power supply can't be restored within 2 hours, the operating personnel will lose the information on plant parameters and hence this is the first cliff-edge effect in case of SBO. For that purpose an improvement measure is proposed for ensuring an alternative source for battery recharging. (page 15.) | | |
| 3.2.3.2.3 | For both NPPs: It is recommended, that the SUJB consider how to monitor the licensee in respect: • to increase the plant robustness by implementation of alternative means for AC power supply for core cooling and heat removal to improve the battery depletion time and implement battery recharging. (page 17.) | | |
| 3.2.3.3 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.2.3.3.1 | Improving the battery depletion time and implement battery recharging by SBO DG (page 4.) | | |
| | | | |

| 3.2.4 Operational and Preparatory Actions | | | |
|---|--|---------------------------|---------------|
| Operational and Preparatory Actions | | 22 | design issues |
| Implementation of operational or preparatory actions with respect to the availability of operational consumables. | | | |
| | | | |
| 3.2.4.1 | Recommendations from National Stress test Report | | |
| 3.2.4.1.1 | NPP Temelin: Alternative supply of diesel fuel from a tank truck for long-term operation of the DG (tab.34) | | |
| 3.2.4.2 | Luxembourg general peer review report | | |
| 3.2.4.2.1 | Operational or preparatory actions such as ensuring the supply of fuel and lubrication oil, battery load-shedding to extend battery life are examples of measures that are small (in many cases procedural) but that could make a considerable difference in response to initiators. All in all, most of the plants have already considered these measures and might be adding to them in the future. (§6.3.3) | | |
| 3.2.4.3 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.2.4.3.1 | Developing procedures for complex accidents (e.g. loss of UHS and ESW systems, procedure for the alternative replenishment of water to steam generator/SFP/primary circuit (with unsealed primary circuit, use of mobile DGs during SBO's, long term DG operation.) (page 3.) | | |
| | | | |
| 3.2.5 Instrumentation and Monitoring | | | |
| Instrumentation and Monitoring | | 23, 24, 25, 26, 27 | design issues |
| The enhancement of instrumentation and monitoring. | | | |
| | | | |

| | | | |
|---|--|---------------|---------------|
| 3.2.6 Shutdown Improvements | | | |
| Shutdown Improvements The enhancement of safety in shutdown states and mid-loop operation. | | 28 | design issues |
| | | | |
| 3.2.6.1 | Recommendations from National Stress test Report | | |
| 3.2.6.1.1 | NPP Dukovany: Prepare “shutdown SAMG” for shutdown / Severe accident in SFSP (tab.22) | | |
| 3.2.6.1.2 | NPP Temelin: Procedure for the isolation of the containment when in shutdown (tab.34) | | |
| 3.2.6.1.3 | NPP Temelin: Execute “SAMG shutdown” (fuel degradation with open reactor/in SFSP (tab.36) | | |
| 3.2.6.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.6.2.1 | For both NPPs: • development of SAMGs for shutdown modes including open reactor and SFP accidents; (page 25.) | | |
| | | | |
| 3.2.7 Reactor Coolant Pump Seals | | | |
| Reactor Coolant Pump Seals The use of temperature-resistant (leak-proof) primary pump seals. Study of RCP pump seal leakage following long term AC power failure. | | | design issues |
| | VVER reactor designs do not include mechanical reactor coolant pump seals. The sealing of the MCPs is assured by high pressure water dependent on AC/DC power supplies. The existing studies of seals behaviour in case of loss of AC/DC will be reviewed and upgraded including definition of potentially necessary remedial measures | | |
| 3.2.8 Ventilation | | | |
| Ventilation The enhancement of ventilation capacity during SBO to ensure equipment operability. | | 29, 30 | design issues |

| | | | |
|---|---|-----------|---------------|
| | | | |
| 3.2.8.1 | Recommendations from National Stress test Report | | |
| 3.2.8.1.1 | NPP Temelin: Analysis of heat transfer from the I&C after losing the ESW (tab.34) | | |
| 3.2.8.2 | Recommendations from ENSERG Country Peer Review | | |
| 3.2.8.2.1 | NPP Temelin: Analysis of heat removal from I&C systems following a loss of ESW (page 17.) | | |
| 3.2.8.3 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.2.8.3.1 | Analysis of the heat removal from I&C systems following a loss of ESW (page 3.) | | |
| | | | |
| 3.2.9 Main and Emergency Control Rooms | | | |
| Main and Emergency Control Rooms The enhancement of the main control room (MCR), the emergency control room (ECR) and emergency control centre (ECC) to ensure continued operability and adequate habitability conditions in the event of a station black-out (SBO) and in the event of the loss of DC (this also applies to Topic 3 recommendations). Habitability of control rooms/emergency centres under DEC conditions. | | 31 | design issues |
| | | | |
| 3.2.9.1 | Recommendations from National Stress test Report | | |
| 3.2.9.1.1 | NPP Temelin: Analysis of the radiation situation in the CR/ ECR in case of a severe accident (tab.36) | | |
| 3.2.9.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.9.2.1 | For both NPPs: The main control rooms (MCR) and the emergency control rooms (ECR) are equipped with emergency filtered ventilation systems and are shielded and protected sufficiently against radiation. The habitability of the MCR and ECR in case of containment failure during a severe accident has not been analysed. Finally, it is recognized that not all systems used under SAM are designed to withstand earthquakes. It is recommended that the seismic resistance of the systems used for severe accident management should be further analysed. (page 21.) Additional power sources and ventilation systems will be implemented at Dukovany and Temelin NPPs to | | |

| | | | |
|---|---|------------|---------------|
| | ensure continued operability and adequate habitability conditions in the event of a station black-out. | | |
| 3.2.10 Spent Fuel Pool | | | |
| Spent Fuel Pool The improvement of the robustness of the spent fuel pool (SFP). | | 32, | design issues |
| | | | |
| 3.2.10.1 | Recommendations from National Stress test Report | | |
| 3.2.10.1.1 | NPP Dukovany: The existing regulations prefer the way of filling the open reactor and SFSP with self-gravitation from XL trays (tab.17) | | |
| 3.2.10.1.2 | NPP Dukovany: The collection of cooling from SFSP by adding coolant and accumulation in TH tanks (tab.17) | | |
| 3.2.10.1.3 | NPP Dukovany: Prepare “shutdown SAMG” for shutdown / Severe accident in SFSP (tab.21) | | |
| 3.2.10.1.4 | NPP Dukovany: Completion of measurements of the Ra situation and the status of SFSP (tab.21) | | |
| 3.2.10.1.5 | For both NPPs: Alternative water supply for SG/SFSP/I.C (in case of I.C leakage) (tab.34) | | |
| 3.2.10.1.6 | NPP Temelin: Transfer of heat from the SFSP without an additional water supply (tab.34) | | |
| 3.2.10.1.7 | NPP Temelin: Execute “SAMG shutdown” (fuel degradation with open reactor/in SFSP) (tab.36) | | |
| 3.2.10.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.10.2.1 | NPP Dukovany: Filling an open reactor and spent fuel pool (SFP) by gravity drainage from bubbler trays (page 17.) | | |

| | | | |
|--|---|-----------|---------------|
| 3.2.10.2.2 | NPP Dukovany: Removal of heat from the coolant in the SFP by means of coolant replenishment and its accumulation in emergency cooling water tanks (TH-system) | | |
| 3.2.10.2.3 | NPP Dukovany: Extensive damage mitigation guidelines for the use of alternative means | | |
| 3.2.10.2.4 | NPP Dukovany: Improvement of the crisis plans and SAM documentation (e.g., providing SAMG for shutdown states and spent fuel pool accidents) (page 23.) | | |
| 3.2.10.2.5 | NPP Temelin: Alternative replenishment of water to steam generator/SFP/primary circuit (with unsealed primary circuit) (page 17.) | | |
| 3.2.10.2.6 | For both NPPs: Accidents during shutdown states and occurring at the SFP are not addressed in the existing SAMGs, but will be available by 2014. It is recommended that SUJB considers how to monitor the implementation. (page 26.) | | |
| 3.2.10.3 | Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS | | |
| 3.2.10.3.1 | Installing additional equipment and instrumentation in spent fuel pools to ensure cooling can be maintained or restored in all circumstances, or performing additional technical evaluations to determine if additional equipment and instrumentation are needed. (page 6.) | | |
| | | | |
| 3.2.11 Separation and Independence | | | |
| Separation and Independence The enhancement of the functional separation and independence of safety systems. | | 33 | design issues |
| | | | |
| 3.2.11.1 | Recommendations from National Stress test Report | | |
| 3.2.11.1.1 | NPP Dukovany: Implementation of measures for diversified means of the ultimate heat sink (to CT) (tab.17) | | |
| 3.2.11.2 | Recommendations from ENSREG Country Peer Review | | |

| | | | |
|---|---|---------------------------|---------------|
| 3.2.11.2.1 | <p>NPP Dukovany: In Dukovany NPP there are 4 wet cooling towers for twin units, which serve as heat sink for service water and also for essential service water (TVD) systems. Cooling towers are not qualified as safety components. This issue was recognized during the last periodic safety review in 2009, and is being addressed by the project “Separation of safety systems from operational systems” (No. 5983). As it was discussed during the country visit, this safety improvement project is currently in design phase; the hardware modification is scheduled from 2015 to 2017. It is recommended, that the regulator considers how to ensure this is resolved effectively. (page 15.)</p> | | |
| 3.2.12 Flow Path and Access Availability | | | |
| <p>Flow Path and Access Availability The verification of assured flow paths and access under SBO conditions. Ensure that the state in which isolation valves fail and remain, when motive and control power is lost, is carefully considered to maximise safety. Enhance and extend the availability of DC power and instrument air (e. g. by installing additional or larger accumulators on the valves). Ensure access to critical equipment in all circumstances, specifically when electrically operated turnstiles are interlocked.</p> | | 34, 35, 36, 37, 76 | design issues |
| | | | |
| 3.2.12.1 | Recommendations from National Stress test Report | | |
| 3.2.12.1.1 | <p>NPP Dukovany: Ensuring alternative source of electricity for safe places and telephone exchanges (tab.16)</p> | | |
| 3.2.12.1.2 | <p>NPP Dukovany: Ensuring sufficient personnel during long-term SBO (tab.16)</p> | | |
| 3.2.12.1.3 | <p>NPP Temelin: Securing a sufficient number of staff in case of a long-term SBO (tab.34)</p> | | |
| 3.2.12.2 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.2.12.2.1 | Valves power reconnection to batteries for containment isolation during SBO (page 4.) | | |
| | | | |

| 3.2.13 Mobile Devices | | | |
|---|---|---------------|---------------|
| Mobile Devices The provision of mobile pumps, power supplies and air compressors with prepared quick connections, procedures, and staff training with drills. | | 38, 39 | design issues |
| | | | |
| 3.2.13.1 | Recommendations from National Stress test Report | | |
| 3.2.13.1.1 | NPP Dukovany: Ensuring additional supply source for systems SPS I. category and selected consumer appliances SPS II. category (tab.16) | | |
| 3.2.13.1.2 | NPP Dukovany: Ensuring additional sources for water supply including corresponding procedures and guidelines and availability of trained and qualified personnel (tab.16) | | |
| 3.2.13.1.3 | NPP Dukovany: Ensuring alternative source of electricity for safe places and telephone exchanges (tab.16) | | |
| 3.2.13.1.4 | NPP Dukovany: Ensuring alternative source of electricity for the TSPP supply (tab.16) | | |
| 3.2.13.1.5 | NPP Temelin: Alternative supply of diesel fuel from a tank truck for long-term operation of the DG (tab.34) | | |
| 3.2.13.1.6 | NPP Temelin: Alternative water supply for SG/SFSP/I.C (in case of I.C leakage) including corresponding procedures and guidelines and availability of trained and qualified personnel (tab.34) | | |
| 3.2.13.1.7 | NPP Temelin: Alternative source for recharging accumulator batteries and supplying selected appliances (tab.34) | | |
| 3.2.13.2 | Recommendations from EENSREG Country Peer Review | | |
| 3.2.13.2.1 | For both NPPs: In particular, the following measures have to be implemented: providing mobile (portable) equipment for ensuring feasibility of the SAM actions (page 25.) | | |

| | | | |
|--|---|--|---------------|
| 3.2.13.2.2 | <p>For both NPPs:</p> <ul style="list-style-type: none"> increase robustness of storage building structures for mobile devices including fire trucks, or relocation of equipment (page 25.) | | |
| 3.2.13.3 | Luxembourg general peer review report | | |
| 3.2.13.3.1 | That the design for storage of mobile equipment to perform necessary safety functions should take account of external events at the design and beyond design levels, to ensure appropriate availability in the event of being required following a significant external event. Similar considerations apply for external hazards robustness of on-site centres for SAM. (§ 5.3.9) | | |
| 3.2.13.3.2 | Availability of a variety of mobile devices, with prepared quick connections, procedures on how to connect and use and staff training for deployment of such equipment. It is important that the equipment is to be stored in locations that are safe and secure even in the event of general devastation caused by events (significantly) beyond the design basis. Mobile sources of power would enable the use of existing equipment; mobile pumps would enable direct feeding of the primary or secondary side, even using alternative sources of water. Mobile battery chargers or mobile DC power sources will allow extended use of instrumentation and operation of controls. Fire-fighting equipment, including fire trucks, diesel pumps, generators, emergency lighting, etc., is normally readily available at the plants. Engineered and prepared connections as well as drills on the use of this equipment significantly add to the robustness for BDB events. (§6.3.1) | | |
| 3.2.14 Bunkered/Hardened Systems | | | |
| <p>Bunkered/Hardened Systems</p> <p>The provision for a bunkered or “hardened” system to provide an additional level of protection with trained staff and procedures designed to cope with a wide variety of extreme events including those beyond the design basis (this also applies to Topic 3 recommendations).</p> | | <p>13, 14, 15, 16, 17, 18, 19, 20, 21, 33, 40, 41, 42, 43, 56</p> | design issues |
| 3.2.14.1 | Recommendations from National Stress test Report | | |
| 3.2.14.1.1 | <p>NPP Dukovany:</p> <p>Alternative means of communications after a seismic event (tab.10)</p> | | |

| | | | |
|--|--|---------------|---------------|
| 3.2.14.1.2 | NPP Dukovany: Analysis regarding threat to shelters in the case of floods (tab.11) | | |
| 3.2.14.1.3 | NPP Temelin: Analysis of the threat to the shelters in case of a seismic event (tab.30) | | |
| 3.2.14.1.4 | NPP Temelin: Analysis of the threat to the shelters in case of floods (tab.31) | | |
| 3.2.14.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.14.2.1 | For both NPP: Some modifications to emergency procedures and analyses regarding the usability of the shelters under flooding conditions are foreseen. (page 10) | | |
| 3.2.14.2.2 | NPP Temelin: Increasing the protection of the diesel fuel pumps against the effects of flooding and also an alternative shelter is to be set up for the emergency response organization when the dedicated emergency response centre is damaged due to some external hazard. (page 10) | | |
| 3.2.14.3 | Luxembourg general peer review report | | |
| 3.2.14.3.1 | That some countries have proposed to develop a “hardened core” of selected safety systems protected against extreme hazards. (§ 5.3.8) | | |
| 3.2.14.3.2 | Within the stress tests evaluation the bunkered system proved its worth in ensuring an additional level of protection, able to cope with a variety of initiators, including those beyond the design basis. The concept is taken even further in the form of the "hardened core" where in addition to equipment, trained staff and procedures designed to cope with a wide variety of extreme events will be available. (§ 6.3.4) | | |
| 3.2.15 Multiple Accidents | | | |
| Multiple Accidents The enhancement of the capability for addressing accidents occurring simultaneously on all plants of the site and consideration of the site as a whole for a multi-units site in the safety assessment. | | 40, 41 | design issues |
| | | | |

| | | | |
|-------------|--|--|--|
| 3.2.15.1 | Recommendations from National Stress test Report | | |
| 3.2.15.1.1 | NPP Dukovany: Ensuring of sufficient amount of staff after a seismic event (tab.10) | | |
| 3.2.15.1.2 | NPP Dukovany: Ensuring sufficient personnel during long-term SBO (tab.16) | | |
| 3.2.15.1.3 | NPP Dukovany: Preparation of the procedure for the loss of UHS and ESW systems on all 4 units (tab.17) | | |
| 3.2.15.1.4 | NPP Dukovany: Completion of the existing regulations with the procedure for filling SG of all four units by fire extinguishing technology (tab.17) | | |
| 3.2.15.1.5 | NPP Dukovany: Ensuring staffing of CR (tab.21) | | |
| 3.2.15.1.6 | NPP Temelin: Security of the staff after a seismic event (tab.30) | | |
| 3.2.15.1.7 | NPP Temelin: Access to buildings, accessibility for heavy machinery (tab.30) | | |
| 3.2.15.1.8 | NPP Temelin: Ensuring safety and operational staff in case of extreme events (tab.33) | | |
| 3.2.15.1.9 | NPP Temelin: Procedure for restoring the power supply after an SBO in all units (tab.34) | | |
| 3.2.15.1.10 | NPP Temelin: Analyses of the possibility of shift staff in case of an SBO in both units (tab.34) | | |
| 3.2.15.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.15.2.1 | NPP Dukovany: • Develop a procedure for the loss of UHS and ESW systems in all 4 units (page 17.) | | |

| | | | |
|---|---|---------------|---------------|
| 3.2.15.2.2 | NPP Temelin: As it has been already mentioned, nearly all severe accident management measures are dependent on AC power by relying on battery back-up power, local manual operations, diesel generators, pumps etc. If the power supply in both Units is lost, the shift personnel could also be overloaded by activities related to restoring the power supply. This means that the capacity of the personnel on-site would not be sufficient to cope with the multi-Unit accidents. Further measures are foreseen. (page 23.) | | |
| 3.2.15.2.3 | NPP Temelin: • Develop a procedure for the loss of UHS and ESW systems in both units (page 17.) | | |
| 3.2.15.2.4 | For both NPPs: In particular, the following measures have to be implemented: further analyses of the impacts from the infrastructure damages, multiple Unit accidents etc on the SAM and emergency response provisions. (page 25) | | |
| 3.2.15.3 | Luxembourg general peer review report | | |
| 3.2.15.3.1 | The stress tests evaluation identified issues and consequently led to improvements in preparedness for the events that could affect multiple units. Previously, the multi-unit site protections were sometimes designed to cope with a serious challenge facing one of the units. During the stress tests, it was identified that robustness could be enhanced if additional equipment and trained staff were to be made available to deal with events affecting all the units on one site. While the process of improvement is not yet completed, it has been initiated on many sites. (§ 6.3.5) | | |
| 3.2.16 Equipment Inspection and Training Programs | | | |
| Equipment Inspection and Training Programs The establishment of regular programs for inspections to ensure that a variety of additional equipment and mobile devices are properly installed and maintained, particularly for temporary and mobile equipment and tools used for mitigation of BDB external events. Development of relevant staff training programmes for deployment of such devices. | | 42, 43 | design issues |
| 3.2.16.1 | Recommendations from National Stress test Report | | |

| | | | |
|---|--|---------------|---------------|
| 3.2.16.1.1 | NPP Dukovany: Introduction of TSC training in the area of severe accidents (tab.21) | | |
| 3.2.16.1.2 | NPP Temelin: Verification of the system functions in beyond design basis operating states (tab.36) | | |
| 3.2.16.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.16.2.1 | NPP Dukovany: In the area of abilities to manage severe accidents opportunities were identified to increase the safety. This concerns administrative solutions, personnel area as well as hardware. The key proposed measures include: • enhancement of the staff training in SAM field (page 23.) | | |
| 3.2.16.2.2 | NPP Temelin: To manage severe accidents there are still opportunities to increase the safety. This concerns administrative solutions, personnel area as well as hardware. The key proposed measures by the regulatory authority include: • enhancement of the staff training in SAM field (page 23.) | | |
| | For both NPPs: • Implement system for periodic verification of operability of new mobile equipment • Implement system for training of new mobile equipment usage | | |
| 3.2.17 Further Studies to Address Uncertainties | | | |
| Further Studies to Address Uncertainties The performances of further studies in areas where there are uncertainties. Uncertainties may exist in the following areas: · The integrity of the SFP and its liner in the event of boiling or external impact. · The functionality of control equipment (feedwater control valves and SG relief valves, main steam safety valves, isolation condenser flow path, containment isolation valves as well as depressurisation valves) during the SBO to ensure that cooling using natural circulation would not be interrupted in a SBO. · The performance of additional studies to assess operation in the event of widespread damage, for example, the need for different equipment (e.g. bulldozers) to clear the route to the most critical locations or equipment. This includes the logistics of the external support and related arrangements (storage of equipment, use of national defence resources, etc.). | | 44, 45 | design issues |
| | | | |

| | | | |
|-------------|---|--|--|
| 3.2.17.1 | Recommendations from National Stress test Report | | |
| 3.2.17.1.1 | NPP Dukovany: Analyses: Seismic resistance of LFRU building (tab.10) | | |
| 3.2.17.1.2 | NPP Dukovany: Analyses: Seismic PSA (tab.10) | | |
| 3.2.17.1.3 | NPP Dukovany: Analyses: Analysis regarding threat to shelters in the case of floods (tab.11) | | |
| 3.2.17.1.4 | NPP Dukovany: Analyses: Resistance of civil structures (LFRU, CPS, MPU etc.) to extreme conditions (tab.15) | | |
| 3.2.17.1.5 | NPP Dukovany: Analyses: To work out methods of evaluation of external effects, verification of analyses performed, possible technical measures (tab.15) | | |
| 3.2.17.1.6 | NPP Dukovany: Analyses: Analysis of the discharging time of accumulator batteries for the unit for releasing the load, filling OIs , changing the connection and operation of emergency lighting (tab.16) | | |
| 3.2.17.1.7 | NPP Dukovany: Analyses: The collection of cooling from SFSP by adding coolant and accumulation in TH tanks (tab.17) | | |
| 3.2.17.1.8 | NPP Temelin: Analyses: Resilience of the LFRU (local fire rescue unit) to seismicity (tab.30) | | |
| 3.2.17.1.9 | NPP Temelin: Analyses: Access to buildings, accessibility for heavy machinery (tab.30) | | |
| 3.2.17.1.10 | NPP Temelin: Analyses: Analysis of the threat to the shelters in case of floods (tab.31) | | |
| 3.2.17.1.11 | NPP Temelin: Analyses: Executing methodology for assessing external effects, verification of analyses carried out, possible technical measures (tab.33) | | |
| 3.2.17.1.12 | NPP Temelin: Analyses: Analysis of heat transfer from the I&C after losing the ESW (tab.34) | | |

| | | | |
|-------------|--|--|--|
| 3.2.17.1.13 | NPP Temelin: Analyses: Analysis of the discharging period of the accumulator batteries in case of a controlled reduction of the load, details on procedures (tab.34) | | |
| 3.2.17.1.14 | NPP Temelin: Analyses: Transfer of heat from the SFSP without an additional water supply (tab.34) | | |
| 3.2.17.1.15 | NPP Temelin: Analyses: Analyses of the possibility of shift staff in case of an SBO in both units (tab.34) | | |
| 3.2.17.1.16 | NPP Temelin: Analyses: Localization of melt outside the RPV (tab.36) | | |
| 3.2.17.1.17 | NPP Temelin: Analyses: Analysis of the radiation situation in the CR/ ECR in case of a severe accident (tab.36) | | |
| 3.2.17.1.18 | NPP Temelin: Analyses: Analyse the possibility and various alternatives of modifications to complete the original containment design with the feasible venting option for the case of severe accidents (Type II). (page 299.) | | |
| 3.2.17.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.2.17.2.1 | For both NPPs: In particular, the following measures have to be implemented: Further analyses of the impacts from the infrastructure damages, multiple Unit accidents etc on the SAM and emergency response provisions.. (page 25.) | | |
| | | | |

3.3 Topic 3 - Severe accident management

| 3.3.1 WENRA Reference Levels | | | |
|---|--|---------------------|----------------------------|
| No. | Recommendations | Activity Action No. | Topic |
| WENRA Reference Levels The incorporation of the WENRA reference levels related to severe accident management (SAM) into their national legal frameworks, and ensure their implementation in the installations as soon as possible. | | 62 | severe accident management |
| 3.3.1.1 | Luxembourg general peer review report | | |
| 3.3.1.1.1 | In response to their previous commitments, regulators should incorporate the WENRA reference levels related to SAM into their national legal frameworks, and ensure then implementation as soon as possible. (§ 7.3.2) | | |
| 3.3.2 SAM Hardware Provisions | | | |
| SAM Hardware Provisions Adequate hardware provisions that will survive external hazards (e.g. by means of qualification against extreme external hazards, storage in a safe location) and the severe accident environment (e.g. engineering substantiation and/or qualification against high pressures, temperatures, radiation levels, etc), in place, to perform the selected strategies. | | 46, 47, 48, 49, 50 | severe accident management |
| 3.3.2.1 | Recommendations from National Stress test Report | | |
| 3.3.2.1.1 | NPP Dukovany: Increase of the capacity of the system for the liquidation of emergency hydrogen (tab.22) | | |
| 3.3.2.1.2 | NPP Dukovany: Cooling of the melt from the outside of RPV (tab.22) | | |

| | | | |
|-----------|---|--|--|
| 3.3.2.1.3 | NPP Dukovany: Oxygen regeneration in safe places (tab.21) | | |
| 3.3.2.1.4 | NPP Temelin: Alternative supply of water into the containment reservoir (tab.36) | | |
| 3.3.2.1.5 | NPP Temelin: System for the liquidation of hydrogen in the containment in case of a severe accident (tab.36) | | |
| 3.3.2.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.3.2.2.1 | For both NPPs: <ul style="list-style-type: none"> • Re-criticality <p>The normal procedure is to feed borated water into the reactor coolant system. For some circumstances the SAMGs at both sites (Temelin and Dukovany) include the strategies allowing injection of non-borated water into the reactor as a last possibility to cool the fuel or debris at in-vessel phase of severe accident progression. As it has been clarified during the country visit the possibility of re-criticality has been considered by the NPPs and has been excluded based on certain qualitative considerations, although no dedicated detailed analyses have been performed. It is recommended that regulatory authority considers the need of requesting additional investigations of the potential for re-criticality for the correspondent SAM strategies. (page 21.)</p> | | |
| 3.3.2.2.2 | For both NPPs: <ul style="list-style-type: none"> • Control rooms: <p>The main control rooms (MCR) and the emergency control rooms (ECR) are equipped with emergency filtered ventilation systems and are shielded and protected sufficiently against radiation. The habitability of the MCR and ECR in case of containment failure during a severe accident has not been analysed. Finally, it is recognized that not all systems used under SAM are designed to withstand earthquakes. It is recommended that the seismic resistance of the systems used for severe accident management should be further analysed. (page 21.)</p> | | |

| | | | |
|-----------|---|--|--|
| 3.3.2.2.3 | <p>For both NPPs: In particular, the following measures have to be implemented:</p> <ul style="list-style-type: none"> • alternative containment sump water make up (Temelin) • selection and implementation of appropriate solution for protecting containment from the overpressure loads; • providing mobile (portable) equipment for ensuring feasibility of the SAM actions; • ex-vessel cooling at Dukovany NPP • cooling of molten core is still an open issue for Temelin NPP • installation of additional recombiners sufficient for severe accident conditions at Temelin and Dukovany NPPs <p>A filtered venting system to protect the containment against loss of integrity and to reduce significantly the releases of radioactivity to the environment should be analysed in order to determine any appropriate modifications for all units at Temelin NPP and for all units at Dukovany NPP. The current system is not designed for severe accident conditions. The filtered venting system would limit a long-term containment over pressurization resulting from accumulation of non-condensable gases and decay heat, generated inside the containment in case of a severe accident.</p> <p>Implementation of the measures identified during stress tests and recommended during peer review of the national report will ensure robustness of the SAM arrangements of the Dukovany and Temelin NPPs. (page 25.)</p> | | |
| 3.3.2.3 | Luxembourg general peer review report | | |
| 3.3.2.3.1 | Effective implementation of SAM requires that adequate hardware provisions are in place to perform the selected strategies. (§ 7.3.3) | | |
| 3.3.2.3.2 | The means for maintaining containment integrity should in particular include depressurization of the reactor coolant system, prevention of damaging hydrogen explosions, and means of addressing long-term containment over-pressurization, such as filtered venting. (§ 7.3.4) | | |
| 3.3.2.4 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.3.2.4.1 | Selection of appropriate strategy to protect containment against overpressure (filtered venting system is one option) (page 4.) | | |
| 3.3.2.4.2 | Installation of additional sufficient hydrogen recombiners for severe accident conditions (page 4.) | | |
| 3.3.2.4.3 | Instrumentation for SA harsh conditions (Analysis and measures) (page 4.) | | |
| 3.3.2.4.4 | Corium in/ex vessel cooling (page 4.) | | |

| | | | |
|--|---|-----------|----------------------------|
| 3.3.2.5 | Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS | | |
| 3.3.2.5.1 | Upgrading safety systems or installing additional equipment and instrumentation to enhance the ability of each nuclear power plant to withstand an unexpected natural event without access to the electrical power grid for an extended period of time, including for an external event affecting multiple units. (page 6.) | | |
| 3.3.3 Review of SAM Provisions Following Severe External Events | | | |
| Review of SAM Provisions Following Severe External Events The systematic review of SAM provisions focusing on the availability and appropriate operation of plant equipment in the relevant circumstances, taking account of accident initiating events, in particular extreme external hazards and the potential harsh working environment. | | 51 | severe accident management |
| 3.3.3.1 | Recommendations from National Stress test Report | | |
| 3.3.3.1.1 | NPP Temelin: Verification of the system functions in beyond design basis operating states (tab.36) | | |
| 3.3.3.2 | Luxembourg general peer review report | | |
| 3.3.3.2.1 | PSR should continue to be maintained as a powerful regulatory instrument for the continuous enhancement of defence-in-depth in general, and the provisions of SAM in particular. The lessons learned from the Fukushima accident and from the stress tests should be reflected in the scope of future PSRs. (§ 7.3.1) | | |
| 3.3.3.2.2 | A systematic review of SAM provisions should be performed, focusing on the availability and appropriate operation of plant equipment in the relevant circumstances, taking account of accident initiating events, in particular extreme external hazards and the potential harsh working environment. (§ 7.3.5) | | |

| | | | |
|---|--|-------------------|----------------------------|
| 3.3.3.2.3 | The assessment of SAM provisions should take account of the need to work with a severely damaged infrastructure (i.e. in which the usual means of communication and access, etc. are disabled), of plant level, corporate-level and national-level aspects, and of long-duration accidents affecting multiple units at the same time (on individual and nearby sites as appropriate). (§ 7.3.6) | | |
| 3.3.3.3 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.3.3.3.1 | Further analyses of the impacts from the infrastructure damages, multiple Unit accidents etc on the SAM and emergency response provisions. (page 4.) | | |
| 3.3.3.4 | Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS | | |
| 3.3.3.4.1 | Performing or planning an evaluation of the guidance that is to be used by the operator to manage emergency situations resulting from severe accidents caused by extreme natural phenomena at nuclear power plants, including for low power and shutdown states. These documents include emergency operating procedures to prevent core damage, severe accident management guidelines to prevent containment failure, and extensive damage mitigation guidelines to address accidents that result in fires or explosions that affect a large portion of a nuclear power plant. (page 6.) | | |
| 3.3.4 Enhancement of Severe Accident Management Guidelines (SAMG) | | | |
| Enhancement of Severe Accident Management Guidelines (SAMG) In conjunction with the recommendation 4, the enhancement of SAMGs taking into account additional scenarios, including, a significantly damaged infrastructure, including the disruption of plant level, corporate-level and national-level communication, long-duration accidents (several days) and accidents affecting multiple units and nearby industrial facilities at the same time. | | 10, 52, 53 | severe accident management |
| 3.3.4.1 | Recommendations from National Stress test Report | | |
| 3.3.4.1.1 | NPP Dukovany: Prepare “shutdown SAMG” for shutdown / Severe accident in SFSP (tab.21) | | |
| 3.3.4.1.2 | NPP Temelin: Execute “SAMG shutdown” (fuel degradation with open reactor/in SFSP) (tab.36) | | |

| | | | |
|---|--|------------|----------------------------|
| 3.3.4.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.3.4.2.1 | For both NPPs: • development of SAMGs for shutdown modes including open reactor and SFP accidents; (page 25.) | | |
| 3.3.4.3 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.3.4.3.1 | Developing extensive damage mitigation guidelines (page 3.) | | |
| 3.3.4.3.2 | Development of SAMGs for shutdown modes including open reactor, SFP accidents and multi unit accidents (page 4.) | | |
| 3.3.4.4 | Analysis of human resources, communication, personnel training and guidance during severe long term accidents (esp. multi-unit) and validation of effectiveness through exercises. | 54, 55, 60 | severe accident management |
| 3.3.5 SAMG Validation | | | |
| SAMG Validation The validation of the enhanced SAMGs. | | 54 | severe accident management |
| 3.3.5.1 | Luxembourg general peer review report | | |
| 3.3.5.1.1 | The SAMGs should be comprehensively validated taking due account of the potential long duration of the accident, the degraded plant and the surrounding conditions. Pre-planned SAM actions should be designed to function effectively and robustly for suitably lengthy periods following the initiating event. In most cases, durations of at least several days should be assumed for planning and assessment purposes. (§ 7.3.7) | | |
| 3.3.5.2 | Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS | | |
| 3.3.5.2.1 | Developing probabilistic safety assessments to identify additional accident management measures or changes in radiation protection measures for workers on the site that might be needed to perform necessary activities in the event of a severe accident. (page 6.) | | |

| | | | |
|--|--|-----------|----------------------------|
| 3.3.6 SAM Exercises | | | |
| SAM Exercises Exercises aimed at checking the adequacy of SAM procedures and organisational measures, including extended aspects such as the need for corporate and nation level coordinated arrangements and long-duration events. | | 55 | severe accident management |
| | | | |
| 3.3.6.1 | Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS | | |
| 3.3.6.1.1 | Reviewing and updating national, regional, provincial, municipal and local emergency plans and conducting exercises to encourage greater coordination among the different organizations. (page 6.) | | |
| | | | |
| 3.3.7 SAM Training | | | |
| SAM Training Regular and realistic SAM training exercises aimed at training staff. Training exercises should include the use of equipment and the consideration of multi-unit accidents and long-duration events. The use of the existing NPP simulators is considered as being a useful tool but needs to be enhanced to cover all possible accident scenarios. | | 55 | severe accident management |
| | | | |
| 3.3.7.1 | Recommendations from National Stress test Report | | |
| 3.3.7.1.1 | NPP Dukovany: Introduction of TSC training in the area of severe accidents (tab.21) | | |
| 3.3.7.1.2 | NPP Temelin: Appointing qualified and well-trained staff to the ERO (tab.36) | | |
| 3.3.7.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.3.7.2.1 | NPP Dukovany: The key proposed measures include: • enhancement of the staff training in SAM field (page 23.) | | |

| | | | |
|--|--|-----------|----------------------------|
| 3.3.7.2.2 | <p>NPP Temelin: To manage severe accidents there are still opportunities to increase the safety. This concerns administrative solutions, personnel area as well as hardware. The key proposed measures by the regulatory authority include:</p> <ul style="list-style-type: none"> • enhancement of the staff training in SAM field (page 23.) | | |
| 3.3.7.3 | Luxembourg general peer review report | | |
| 3.3.7.3.1 | Training and exercises aimed at checking the adequacy of SAM procedures and organisational measures should include testing of extended aspects such as the need for corporate and national level coordinated arrangements and long-duration events. (§ 7.3.8) | | |
| 3.3.8 Extension of SAMGs to All Plant States | | | |
| Extension of SAMGs to All Plant States The extension of existing SAMGs to all plant states (full and low-power, shutdown), including accidents initiated in SFSPs. | | 56 | severe accident management |
| 3.3.8.1 | Recommendations from National Stress test Report | | |
| 3.3.8.1.1 | <p>NPP Dukovany: Prepare “shutdown SAMG” for shutdown / Severe accident in SFSP (tab.21)</p> | | |
| 3.3.8.1.2 | <p>NPP Dukovany: EDMG manuals for the use of alternative means (tab.21)</p> | | |
| 3.3.8.1.3 | <p>NPP Temelin: Execute “SAMG shutdown” (fuel degradation with open reactor/in SFSP) (tab.36)</p> | | |
| 3.3.8.1.4 | <p>NPP Temelin: EDMG manuals for the use of alternative means (tab.36)</p> | | |
| 3.3.8.2 | Recommendations from ENSREG Country Peer Review | | |

| | | | |
|---|---|-----------|----------------------------|
| 3.3.8.2.1 | <p>NPP Dukovany: In the area of abilities to manage severe accidents opportunities were identified to increase the safety. This concerns administrative solutions, personnel area as well as hardware. The key proposed measures include:</p> <ul style="list-style-type: none"> • improvement of the crisis plans and SAM documentation (e.g., providing SAMG for shutdown states and spent fuel pool accidents) (page 23.) | | |
| 3.3.8.2.2 | <p>NPP Temelin: To manage severe accidents there are still opportunities to increase the safety. This concerns administrative solutions, personnel area as well as hardware. The key proposed measures by the regulatory authority include:</p> <ul style="list-style-type: none"> • improvement of the crisis plans and SAM documentation (e.g., providing SAMG for shutdown states and spent fuel pool accidents) (page 23.) | | |
| 3.3.8.2.3 | <p>For both NPPs: As a result of the stress tests several measures to increase the safety level of the NPPs were identified and will be analysed and implemented in the future. Although the exact list of actions, priorities and schedule of implementation of these measures are still being finalized by the licensee and the regulatory authority, some of them have been clearly specified in the national report. In particular, the following measures have to be implemented:</p> <ul style="list-style-type: none"> • development of SAMGs for shutdown modes including open reactor and SFP accidents (page 25.) | | |
| 3.3.8.2.4 | <p>For both NPPs: Accidents during shutdown states and occurring at the SFP are not addressed in the existing SAMGs, but will be available by 2014. It is recommended that SUJB considers how to monitor the implementation. (page 26.)</p> | | |
| | | | |
| 3.3.9 Improved Communications | | | |
| <p>Improved Communications The improvement of communication systems, both internal and external, including transfer of severe accident related plant parameters and radiological data to all emergency and technical support centre and regulatory premises.</p> | | 57 | severe accident management |

| | | | |
|-----------|---|--|--|
| | | | |
| 3.3.9.1 | Recommendations from National Stress test Report | | |
| 3.3.9.1.1 | NPP Dukovany: Alternative means of communications after a seismic event (tab.10) | | |
| 3.3.9.1.2 | NPP Dukovany: Ensuring alternative means for warning and notification of NPP Dukovany personnel and inhabitants in EPZ (tab.21) | | |
| 3.3.9.1.3 | NPP Dukovany: Ensuring alternative source of electricity for safe places and telephone exchanges (tab.16) | | |
| 3.3.9.1.4 | NPP Temelin: Alternative means of communication after a seismic event (tab.30) | | |
| 3.3.9.1.5 | NPP Temelin: Alternative sources and means of communication after a seismic event (tab.34) | | |
| 3.3.9.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.3.9.2.1 | NPP Dukovany: In the area of abilities to manage severe accidents opportunities were identified to increase the safety. This concerns administrative solutions, personnel area as well as hardware. The key proposed measures include: • additional technical measures (ensuring access to facilities, alternative communication means, etc). (page 23.) | | |
| 3.3.9.2.2 | NPP Temelin: To manage severe accidents there are still opportunities to increase the safety. This concerns administrative solutions, personnel area as well as hardware. The key proposed measures by the regulatory authority include: • additional technical measures (ensuring access to facilities, alternative communication means, etc). (page 23.) | | |
| 3.3.9.3 | ENSREG -Follow-up fact finding site visit NPP Temelin | | |
| 3.3.9.3.1 | Emergency response provisions such as providing long term Communication, alternative means (cell phones, radios, limited wire telephone) etc. (page 3.) | | |

| | | | |
|---|--|---------------------------|----------------------------|
| 3.3.9.4 | Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS | | |
| 3.3.9.4.1 | Improving their radiation monitoring and communications capabilities and enhancing public communications, such as via dedicated public websites. (page 6.) | | |
| | | | |
| 3.3.10 Presence of Hydrogen in Unexpected Places | | | |
| Presence of Hydrogen in Unexpected Places The preparation for the potential for migration of hydrogen, with adequate countermeasures, into spaces beyond where it is produced in the primary containment, as well as hydrogen production in SFPs. | | 46, 47, 48, 49, 50 | severe accident management |
| | | | |
| 3.3.10.1 | Recommendations from National Stress test Report | | |
| 3.3.10.1.1 | NPP Dukovany: Increase of the capacity of the system for the liquidation of emergency hydrogen (tab.22) | | |
| 3.3.10.1.2 | NPP Dukovany: Prepare “shutdown SAMG” for shutdown / Severe accident in SFSP (tab.22) | | |
| 3.3.10.1.3 | NPP Temelin: System for the liquidation of hydrogen in the containment in case of a severe accident (tab.36) | | |
| 3.3.10.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.3.10.2.1 | For both NPPs: • installation of additional recombiners sufficient for severe accident conditions at Temelin and Dukovany NPPs (page 25.) | | |
| | | | |
| 3.3.11 Large Volumes of Contaminated Water | | | |
| Large Volumes of Contaminated Water The conceptual preparations of solutions for post-accident contamination and the treatment of potentially large volumes of contaminated water. | | 68 | severe accident management |
| | | | |
| 3.3.11.1 | Luxembourg general peer review report | | |

| | | | |
|--|---|-----------|----------------------------|
| 3.3.11.1.1 | When developing SAM action plans, conceptual solutions for post-accident fixing of contamination and the treatment of potentially large volumes of contaminated water should be addressed. (§ 7.3.9) | | |
| 3.3.12 Radiation Protection | | | |
| Radiation Protection The provision for radiation protection of operators and all other staff involved in the SAM and emergency arrangements. | | 58 | severe accident management |
| | | | |
| 3.3.12.1 | Recommendations from National Stress test Report | | |
| 3.3.12.1.1 | NPP Dukovany: Completion of measurements of the Ra situation and the status of SFSP (tab.21) | | |
| 3.3.12.1.2 | NPP Temelin: Analysis of the radiation situation in the CR/ ECR in case of a severe accident (tab.36) | | |
| 3.3.12.1.3 | NPP Temelin: Connecting isolation valves of the containment ventilation system to the accumulator batteries (tab.34) | | |
| 3.3.12.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.3.12.2.1 | For both NPPs: The main control rooms (MCR) and the emergency control rooms (ECR) are equipped with emergency filtered ventilation systems and are shielded and protected sufficiently against radiation. The habitability of the MCR and ECR in case of containment failure during a severe accident has not been analysed. Finally, it is recognized that not all systems used under SAM are designed to withstand earthquakes. It is recommended that the seismic resistance of the systems used for severe accident management should be further analysed. (page 21.) | | |
| 3.3.12.3 | Luxembourg general peer review report | | |
| 3.3.12.3.1 | Radiation protection of operators and all other staff involved in the SAM and emergency arrangements should be assessed and then ensured by adequate monitoring, guaranteed habitability of the facilities (hardened on-site emergency response facility with radiation protection) needed for accident control, and suitable availability of protective equipment and training. (§ 7.3.10) | | |
| | | | |

| 3.3.13 On Site Emergency Centre | | | |
|---|---|-----------|----------------------------|
| On Site Emergency Centre The provision of an on-site emergency centre protected against severe natural hazards and radioactive releases, allowing operators to stay onsite to manage a severe accident. | | 59 | severe accident management |
| | | | |
| 3.3.13.1 | Recommendations from National Stress test Report | | |
| 3.3.13.1.1 | NPP Dukovany: To ensure working of emergency response units in case of unavailability of ECC (tab.10) | | |
| 3.3.13.1.2 | NPP Dukovany: Ensuring the functioning of emergency response elements in the case of non-accessibility of ECC (tab.16) | | |
| 3.3.13.1.3 | NPP Temelin: OER (organization of emergency response) ability outside the ECC (emergency control centre) (tab.30) | | |
| 3.3.13.1.4 | NPP Temelin: Ability of the OER to function via the ECC (tab.31) | | |
| 3.3.13.1.5 | NPP Temelin: Ability of the ERO to function outside the ECC (tab.36) | | |
| 3.3.13.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.3.13.2.1 | For both NPPs: Control rooms: The main control rooms (MCR) and the emergency control rooms (ECR) are equipped with emergency filtered ventilation systems and are shielded and protected sufficiently against radiation. The habitability of the MCR and ECR in case of containment failure during a severe accident has not been analysed. Finally, it is recognized that not all systems used under SAM are designed to withstand earthquakes. It is recommended that the seismic resistance of the systems used for severe accident management should be further analysed. (page 21.) | | |
| 3.3.13.3 | Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS | | |
| 3.3.13.3.1 | Upgrading regional, off-site and on-site emergency response centres. (page 6.) | | |
| | | | |

| | | | |
|---|--|-----------|----------------------------|
| 3.3.14 Support to Local Operators | | | |
| Support to Local Operators Rescue teams and adequate equipment to be quickly brought on site in order to provide support to local operators in case of a severe situation. | | 60 | severe accident management |
| | | | |
| 3.3.14.1 | Recommendations from National Stress test Report | | |
| 3.3.14.1.1 | NPP Dukovany: Preparation of agreements with external elements (IRS, army) and nearby NPP. Organizational measures (tab.21) | | |
| 3.3.14.1.2 | NPP Temelin: Prepare agreements with external organisations (IRS, army) close to the NPP. Organizational measures (tab.36) | | |
| 3.3.14.1.3 | To consider the establishment of a common VVER operator center for mutual aid in the case of severe accidents (Dukovany, Bohunice, Mochovce, Paks) (page 299.) | | |
| 3.3.14.2 | Recommendations from ENSREG Country Peer Review | | |
| 3.3.14.2.1 | NPP Dukovany: In the area of abilities to manage severe accidents opportunities were identified to increase the safety. This concerns administrative solutions, personnel area as well as hardware. The key proposed measures include: • completion of off-site places for their use as alternative location for SAM team (page 23.) | | |
| | | | |
| 3.3.15 Level 2 Probabilistic Safety Assessments (PSAs) | | | |
| Level 2 Probabilistic Safety Assessments (PSAs) A comprehensive Level 2 PSA as a tool for the identification of plant vulnerabilities, quantification of potential releases, determination of candidate high-level actions and their effects and prioritizing the order of proposed safety improvements. Although PSA is an essential tool for screening and prioritising improvements and for assessing the completeness of SAM implementation, low numerical risk estimates should not be used as the basis for excluding scenarios from consideration of SAM especially if the consequences are very high. | | 69 | severe accident management |

| | | | |
|--|---|-----------|----------------------------|
| | | | |
| 3.3.15.1 | Recommendations from National Stress test Report | | |
| 3.3.15.1.1 | NPP Dukovany: Seismic PSA (page 79.) | | |
| 3.3.15.2 | Luxembourg general peer review report | | |
| 3.3.15.2.1 | Although PSA is an essential tool for screening and prioritising improvements and for assessing the completeness of SAM implementation, low numerical risk estimates should not be used as the basis for excluding scenarios from consideration of SAM especially if the consequences are very high. (§ 7.3.11) | | |
| 3.3.16 Severe Accident Studies | | | |
| Severe Accident Studies The performance of further studies to improve SAMGs. Examples of areas that could be improved with further studies include: | | 61 | severe accident management |
| 3.3.16.1 | The availability of safety functions required for SAM under different circumstances. | | |
| 3.3.16.2 | Accident timing, including core melt, reactor pressure vessel (RPV) failure, basement melt-through, SFP fuel uncover, etc. | | |
| 3.3.16.3 | PSA analysis, including all plant states and external events for PSA levels 1 and 2. | | |
| 3.3.16.4 | Radiological conditions on the site and associated provisions necessary to ensure MCR and ECR habitability as well as the feasibility of AM measures in severe accident conditions, multi-unit accidents, containment venting, etc. | | |
| 3.3.16.5 | Core cooling modes prior to RPV failure and of re-criticality issues for partly damaged cores, with un-borated water supply. | | |
| 3.3.16.6 | Phenomena associated with cavity flooding and related steam explosion risks. | | |
| 3.3.16.7 | Engineered solutions regarding molten corium cooling and prevention of basemat melt-through. | | |
| 3.3.16.8 | Severe accident simulators appropriate for NPP staff training. | | |
| 3.3.16.9 | xCNS: Filtration efficiency; R&D related to: • In vessel corium retention • Hydrogen risk studies (e.g. large scale test...) | | |
| | | | |

PART II

4. Issues from CNS EOM Group discussions

| 4.1 Topic 4 - National organisations | | | |
|---|--|----------------------------|------------------------|
| No. | Recommendations | Activity Action No. | Topic |
| 4.1.1 | <p>Review and revision of nuclear Laws, Regulations and Guides.</p> <ul style="list-style-type: none"> • Where the RB is constituted of more than one entity, it is important to ensure efficient coordination. • Emphasis on the need for comprehensive periodic reviews of safety, using state-of-the-art techniques. • To remind CP that national safety frameworks include the RB, TSO and Operating Organisations. <p>- Wide participation in safety networks for operating organizations, RB and TSOs will strengthen them.</p> | 62 | national organisations |
| 4.1.2 | <p>Changes to functions and responsibilities of the RB.</p> <ul style="list-style-type: none"> • Effective independence of the RB is essential, including the following aspects: <ul style="list-style-type: none"> - Transparency in communicating its regulatory decisions to the public. - Competent and sufficient human resources. - Adequate legal powers (e.g. suspend operation). - Financial resources. | 62 | national organisations |
| 4.1.3 | <p>Importance of inviting IRRS missions, and to:</p> <ul style="list-style-type: none"> • Effectively implement the findings. • Make the findings and their means of resolution publicly available. • Invite follow -up missions. | 71 | national organisations |

| | | | |
|-------|---|----|------------------------|
| 4.1.4 | <p>Review and improvements to aspects of National EP&R</p> <ul style="list-style-type: none"> • How to routinely exercise: <ul style="list-style-type: none"> - All involved organizations, up to ministerial level - Scenarios based on events at multi-unit sites • How to train intervention personal for potentially severe Accident conditions • Rapid intervention team to provide support to sites • Determination of the size of the EPZ is variable • Trans- border arrangements need to be further considered and exercised • The use of regional centres to provide support to sites • Education of the public and the media in aspects related to emergencies (e.g. radiation does and their effects) | 66 | national organisations |
| 4.1.5 | <p>Openness, transparency and communication improvements:</p> <ul style="list-style-type: none"> • Communication with stakeholders is a continuous activity not just in an emergency • Active stakeholder engagement in the decision-making process builds public confidence • International bilateral cooperation can be beneficial (e.g. joint regulatory inspections) • The proper balance of understandable information provided to informed groups and the general public needs to be addressed • The transparency of the operators activities needs to be enhanced. | 63 | national organisations |
| 4.1.6 | <p>Post- Fukushima safety reassessments and action plans.</p> <ul style="list-style-type: none"> • All CP should perform a safety reassessment and the resolution of their findings should be progressed through a national action plan or other transparent means and should not be limited to NPPs in operation. • Established safety networks should be efficiently used by CP to disseminate and share relevant information. | 72 | national organisations |
| 4.1.7 | <p>Human and organizational factors (HOF)</p> <ul style="list-style-type: none"> • There is a need to further develop human resource capacity and competence across all organizations in the field of nuclear safety. • Governmental level commitment is needed to ensure along-term approach is developed for capacity building. • Collaborative work is needed in the area of improving and assessing HOF, including safety culture. • The role of sub-contractors may be important; can they be harnessed quickly? | 64 | national organisations |

| No. | Recommendations | Activity Action No. | Topic |
|--|--|---------------------|-------|
| 4.2 Topic 5 - Emergency Preparedness and Response | | | |
| 4.2.1 | Expansion of the set of scenarios on which the plan was based – NPP PLUS Infrastructure / NPP PLUS chemical plant | 66 | EP&R |
| 4.2.2 | Increasing the scope of off-site exercise programs to reflect NPP plus external infrastructure simultaneous problems | 66 | EP&R |
| 4.2.3 | Blending mobile resources into planning and drill programs | 42, 43 | EP&R |
| 4.2.4 | Increasing emphasis on drilling with neighbouring countries | 66 | EP&R |
| 4.2.5 | Exercising all interface points (national, regional, municipal,..) | 66 | EP&R |
| 4.2.6 | Performing of longer term exercises to reflect the challenges of extreme events | 66 | EP&R |
| 4.2.7 | Enhancing radiation monitoring and communication systems by additional diversification / redundancy | 23, 24, 57 | EP&R |
| 4.2.8 | Development of a common source term estimation approach | | EP&R |
| 4.2.9 | Provide access to a “big picture” (international picture) of radiological conditions | | EP&R |
| 4.2.10 | Development of reference level for trans-border processing of goods and services such as container transport | | EP&R |
| 4.2.11 | Re-examination of approach and associated limits to govern the “remediation” phase | | EP&R |
| 4.2.12 | Develop criteria for the return to evacuated area and criteria for return to normal from emergency state | | EP&R |
| 4.2.13 | Improvement of the approach to establish contamination monitoring protocols and locations during the recovery phase | | EP&R |

| | | | |
|--------|--|--------|------|
| 4.2.14 | Hardening of support infrastructure (Emergency Response Centres, Sheltering facilities, essential support facilities (like Corporate Offices) with back-up power, environmental radiological filtering, etc. | 34, 35 | EP&R |
| 4.2.15 | Analyzing medical and human aspects of response to support Emergency workers | | EP&R |
| 4.2.16 | Implementation of processes to enable access to inter-country support including customs processes for access for diplomats and emergency response personal | | EP&R |
| 4.2.17 | Systematic assessment of all aspects of organizations that contribute to emergency response using tools like job and task analysis | | EP&R |
| 4.2.18 | Develop radiological reference levels for rescue and emergency response personnel in extreme events | | EP&R |
| 4.2.19 | Develop reference levels for the application of immediate countermeasures such as sheltering, iodine distribution and evacuation | | EP&R |
| | | | |

4.3 Topic 6 - International Cooperation

| | | | |
|-------|--|----|---------------------------|
| 4.3.1 | <p>Strengthening the peer reviews process of CNS and of missions (IAEA, WANO and Industry)</p> <ul style="list-style-type: none"> • Effectiveness of IAEA peer review processes should be reviewed in response to concerns raised by the public and Non Governmental Organizations. • The CNS national reports should include how peers review and mission findings have been addressed. • Processes and initiatives should be strengthened to ensure implementation of findings of the peer review and missions. • CNS review meetings should ensure robust peer reviews and reporting of peer review results and findings. | 67 | International Cooperation |
| 4.3.2 | <p>Strengthening the peer reviews process of CNS and of missions (IAEA, WANO and Industry) - continue</p> <ul style="list-style-type: none"> • Plant design safety features and related modifications should be considered in WANO and OSART missions. • Better coordination of WANO and IAEA peer review activities should be established. • International experience gained from the review of Russian designs after Chernobyl could be considered as an example of good international practice. | 67 | International Cooperation |

| | | | |
|-------|---|----|---------------------------|
| 4.3.3 | <p>Optimisation of the Global Safety Regime</p> <ul style="list-style-type: none"> • Primary responsibility for safety remains with operators. • The collective responsibility of the various institutions and organizations should be optimized. • The growing number of international meetings, assessments, peer reviews and expanding mandates is placing high demands on existing human resources, which may become counter productive. • Efforts should be continued to reduce duplication of initiatives and actions by various organizations such as IAEA, NEA, EU, WANO, etc. • The respective roles and objectives of the various organizations, institutions and missions should be recognized in the optimization process. | 67 | International Cooperation |
| 4.3.4 | <p>Strengthening communication mechanisms through regional and bilateral cooperation</p> <ul style="list-style-type: none"> • Initiatives relating to the Regional Crisis centre for operators of NPPs with VVER type reactors as being implemented by Moscow WANO Centre and also considered by some other vendor countries. • Bilateral agreements between vendor countries and new embarking countries, complemented by IAEA Standards and review processes, have been reported to be effective and should be encouraged. • Strong support of political leaders is important to establish the necessary nuclear safety infrastructure. • Countries with established nuclear programmes should assist with the establishment of nuclear and regulatory infrastructure. • Countries should cooperate with neighbouring and regional countries and exchange information on their civil nuclear power programmes. | 67 | International Cooperation |
| 4.3.5 | <p>Effectiveness of experience feedback mechanisms</p> <ul style="list-style-type: none"> • Information exchange and feedback should be enhanced by using the established mechanisms (e.g. IRS, INES) and organisations (eg. WANO). • The sharing and utilisation of information is limited and not always necessarily well coordinated or disseminated. This has been identified as an area for improvement. • All nuclear power plants should share Operating Experience. • The current focus is on reporting events and not necessarily on learning from the events. Effectiveness of Operating Experience Feedback should be assessed and its implementation should be included in peer reviews. | 67 | International Cooperation |

| | | | |
|-------|---|----|---------------------------|
| 4.3.6 | <p>Strengthening and expanded use of IAEA Safety Standards</p> <ul style="list-style-type: none"> • The Safety Fundamentals remain appropriate as a sound basis for nuclear safety when properly implemented. • Implementation should strike the right balance between prevention and mitigation. • The IAEA Safety Standards should be taken into account in developing national nuclear safety regulations. • These Safety Standards have a role to play in seeking continuous improvements to safety at existing nuclear power plants. | 62 | International Cooperation |
| | | | |

Part III

| | | | |
|--------------------------------|---|----|----------------------|
| 5. Cross-cutting issues | | | |
| 5.1 4.4.1 | Public discussion of safety issues should be encouraged (Transparency) | 63 | cross-cutting issues |
| 5.2 4.4.2 | An open and trustful relationship between regulators, operators and the public with keeping in mind their respective roles and functions is essential | 65 | cross-cutting issues |
| 5.3 4.4.3 | Recognizing differences in national cultures, each CPs should define appropriate actions to ensure that the desired safety culture characteristics are achieved in the regulatory and operational organizations | 64 | cross-cutting issues |
| | | | |

PART IV

6. Implementation Activities - Actions

| Action No. | Plant / Typ | Topic | Action / Activity | Recommendation No. | Status | Completion |
|------------|---------------|-----------------|---|--------------------|-------------|------------|
| 1 | EDU / PWR | natural hazards | Structures reinforcement against extreme climatic phenomena | 3.1.1 | in progress | 2014 |
| 2 | ETE / PWR | natural hazards | Fire brigade building reinforcement Note: Current solution is a light construction on space | 3.1.1 | in progress | 2014 |
| 3 | EDU / PWR | natural hazards | Fire brigade building reinforcement | 3.1.1 | in progress | 2015 |
| 4 | EDU&ETE / PWR | natural hazards | In the study PSA to evaluate the risk resulting from the induced floods or fires after the seismic event | 3.1.2, 3.1.3 | in progress | 2014 |
| 5 | EDU&ETE / PWR | natural hazards | Ensuring the availability of regional weather forecasts and predictions for the shift engineer decision on the future operation and activities at the NPP | 3.1.3 | in progress | 2013 |
| 6 | EDU / PWR | natural hazards | Implementation of internal seismic monitoring system | 3.1.5 | in progress | 2014 |
| 7 | EDU / PWR | natural hazards | Completion of the procedures for managing extreme conditions in the site (wind, temperature, snow, earthquake) | 3.1.6 | in progress | 2013 |
| 8 | ETE / PWR | natural hazards | Completion of the procedures for managing extreme conditions in the site (wind, temperature, snow, earthquake) | 3.1.6 | in progress | 2013 |
| 9 | EDU&ETE / PWR | natural hazards | Technology hardening against flooding (Temelin Diesel generator station, Dukovany Emergency control centre) | 3.1.7 | in progress | 2012 |

| | | | | | | |
|-----------|---------------|-----------------|--|---------------|-------------|-----------|
| 10 | EDU / PWR | natural hazards | Hardening of entrances to the cable ducts against flooding – extreme rainfall | 3.1.7 | in progress | 2013 |
| 11 | EDU / PWR | natural hazards | Hardening of entrances to the diesel generator station against flooding – extreme rainfall | 3.1.7 | in progress | 2013 |
| 12 | EDU&ETE / PWR | natural hazards | Creation of (in cooperation with the others operator / regulators) methodology for evaluation of design resistance to natural hazards, including acceptance criteria | 3.1.8 | in progress | 2013 |
| 13 | EDU / PWR | design issues | Provision of back-up water supply into SG from external mobile equipment using external connection points | 3.2.1, 3.2.14 | implemented | 2012 |
| 14 | ETE / PWR | design issues | Provision of back-up water supply into SG from external mobile equipment using external connection points | 3.2.1, 3.2.14 | in progress | 2013 |
| 15 | EDU / PWR | design issues | Provision of back-up coolant supply into depressurised reactor and storage pools with additional and sufficient sources of coolant | 3.2.1,3.2.14 | in progress | 2013-2014 |
| 16 | ETE / PWR | design issues | Provision of back-up coolant supply into depressurised reactor and storage pools with additional and sufficient sources of coolant | 3.2.1, 3.2.14 | in progress | 2013-2014 |
| 17 | EDU / PWR | design issues | Emergency cooling method – implementation of another ultimate emergency feedwater pump to SG | 3.2.1, 3.2.14 | in progress | 2013-2015 |
| 18 | EDU / PWR | design issues | Implementation of additional stable source of power supply (SBO-DG) for subsequent increasing of resistant against „station blackout“ scenario | 3.2.2, 3.2.14 | in progress | 2013-2014 |
| 19 | ETE / PWR | design issues | Implementation of additional stable source of power supply (SBO-DG) for subsequent increasing of resistant against „station blackout“ scenario | 3.2.2, 3.2.14 | in progress | 2013-2014 |
| 20 | EDU / PWR | design issues | Implementation of alternative measures to ensure recharging batteries in case SBO and implementation of measures to extend batteries discharging time | 3.2.3, 3.2.14 | in progress | 2012-2016 |

| | | | | | | |
|-----------|---------------|---------------------|---|----------------|-------------|-----------|
| 21 | ETE / PWR | design issues | Implementation of alternative measures to ensure recharging batteries in case SBO and implementation of measures to extend batteries discharging time | 3.2.3, 3.2.14 | in progress | 2013-2014 |
| 22 | EDU&ETE / PWR | design issues | Provision of alternative fuel filling for long-term operation of DG including providing of fuel sources | 3.2.4 | in progress | 2013 |
| 23 | EDU / PWR | design issues, EP&R | Provision of alternative methods of monitoring of key parameters necessary for technological accidents management | 3.2.5, 4.2.7 | implemented | |
| 24 | ETE / PWR | design issues, EP&R | Provision of alternative methods of monitoring of key parameters necessary for technological accidents management | 3.2.5, 4.2.7 | in progress | 2012 |
| 25 | EDU / PWR | design issues | Provision of heat removal from the I&C systems for long-term monitoring of key parameters during SBO | 3.2.5 | in progress | 2013-2015 |
| 26 | ETE / PWR | design issues | Provision of heat removal from the I&C systems for long-term monitoring of key parameters during SBO | 3.2.5 | in progress | 2013-2015 |
| 27 | EDU / PWR | design issues | Implementation of important measurements into post-accident monitoring system – the addition of RA situation measurement and SFP condition into PAMS | 3.2.5 | in progress | 2013-2015 |
| 28 | ETE / PWR | design issues | Do not schedule the modes of operation in mid-loop during shutdown unit state (organizational measure) | 3.2.6 | implemented | |
| 29 | EDU / PWR | design issues | Provision of heat removal from the key safety component during SBO | 3.2.8 | in progress | 2015 |
| 30 | ETE / PWR | design issues | Provision of heat removal from the key safety component during SBO | 3.2.8 | in progress | 2015 |
| 31 | EDU / PWR | design issues | Completion of the project of control rooms habitability | 3.2.9 | in progress | 2015 |
| 32 | EDU / PWR | design issues | Completion of SFP status parameters and the other important measurements into PAMS | 3.2.10 | in progress | 2013-2015 |
| 33 | EDU / PWR | design issues | Implementation of the ventilator towers for ensuring independent ultimate heat sink | 3.2.11, 3.2.14 | in progress | 2014-2016 |

| | | | | | | |
|-----------|---------------|---------------------|---|-----------------------|-------------|-----------|
| 34 | EDU / PWR | design issues, EP&R | Provision of back-up power supply of Security Technical Systems and shelters and power supply of telephone exchanges, communications, lighting, turnstiles | 3.2.12, 4.2.14 | in progress | 2013-2014 |
| 35 | ETE / PWR | design issues, EP&R | Provision of back-up power supply of telephone exchanges, communications and radio network | 3.2.12, 4.2.14 | in progress | 2013-2014 |
| 36 | ETE / PWR | design issues | Ensuring the availability of personnel for long-term support of solving difficult technological extraordinary events - sufficient capacity and expertise of personnel at the whole affected site - long-term external technical capacity and professional support of the site | 3.2.12 | in progress | 2013 |
| 37 | EDU / PWR | design issues | Ensuring the availability of personnel for long-term support of solving difficult technological extraordinary events - sufficient capacity and expertise of personnel at the whole affected site - long-term external technical capacity and professional support of the site | 3.2.12 | in progress | 2013 |
| 38 | EDU / PWR | design issues | Provision of alternative mobile devices for alternative fluids pump and provision of power supply | 3.2.13 | in progress | 2014 |
| 39 | ETE / PWR | design issues | Provision of alternative mobile devices for alternative fluids pump and provision of power supply | 3.2.13 | in progress | 2014 |
| 40 | EDU / PWR | design issues | Ensuring of sufficient capacity and expertise of personnel for multi-unit accident and for the whole site affected | 3.2.15, 3.2.14 | in progress | 2014 |
| 41 | ETE / PWR | design issues | Ensuring of sufficient capacity and expertise of personnel for multi-unit accident and for the whole site affected | 3.2.15, 3.2.14 | in progress | 2014 |
| 42 | EDU&ETE / PWR | design issues, EP&R | Provision of periodic verification of the functionality of alternative mobile devices for mitigation of damage | 3.2.16, 3.2.14, 4.2.3 | in progress | 2015 |
| 43 | EDU&ETE / PWR | design issues, EP&R | Provision of periodic practicing of the using of alternative mobile devices for mitigation of damage | 3.2.16, 3.2.14, 4.2.3 | in progress | 2015 |

| | | | | | | |
|-----------|---------------|---------------|---|----------------|-------------|---------------------------|
| 44 | EDU&ETE / PWR | design issues | Analyze states of severe accidents according to the current “state of art” to reduce uncertainty in the resistance of equipment and in the preparation of procedures for the activities management | 3.2.17 | in progress | constantly |
| 45 | EDU&ETE / PWR | design issues | Assessment of seismic hazard of sites | 3.2.17 | in progress | 2012 |
| 46 | EDU / PWR | SAM | Completion of projects of increase the capacity of the system for the hydrogen disposal during severe accidents | 3.3.2, 3.3.10 | in progress | 2013-2015 |
| 47 | ETE / PWR | SAM | Completion of projects of increase the capacity of the system for the hydrogen disposal during severe accidents | 3.3.2, 3.3.10 | in progress | 2013-2015 |
| 48 | EDU / PWR | SAM | Implementation of external RPV cooling – melted core detention inside RPV (Installation of means for flooding A004, modification of RPV heat shield) | 3.3.2, 3.3.10 | in progress | 2015 |
| 49 | ETE / PWR | SAM | Implementation of analysis and propose a strategy and schedule for implementation of measures for preservation of long-term containment integrity (to stabilize melt and prevent overpressure) | 3.3.2, 3.3.10 | in progress | 2014 |
| 50 | ETE / PWR | SAM | Implementation of measures for maintaining long-term containment integrity according to selected severe accident management strategies | 3.3.2, 3.3.10 | in progress | according to the schedule |
| 51 | ETE / PWR | SAM | Verification of the correctness of assumptions about the functioning of the equipment during beyond design conditions and external risks, including possible measures to ensure functionality according to SAMG | 3.3.3 | in progress | 2014 |
| 52 | EDU&ETE / PWR | SAM | Issuance of a new procedure for coping with extreme conditions at sites (wind, temperature, snow, earthquake) | 3.3.4 | in progress | 2013 |
| 53 | EDU&ETE / PWR | SAM | Processing of guides for the use of alternative technical means (EDMG) | 3.3.4 | in progress | 2015 |
| 54 | EDU&ETE / PWR | SAM | System setup of SAMG verification and validation | 3.3.5, 3.3.4.4 | in progress | 2014 |

| | | | | | | |
|-----------|---------------|---|--|----------------------------|-------------|-----------------|
| 55 | EDU&ETE / PWR | SAM | System setup of training (drills), exercises and training for severe accident management according to SAMG, including the possible solutions of multi-unit severe accident | 3.3.6, 3.3.7, 3.3.4.4 | in progress | 2014 |
| 56 | EDU&ETE / PWR | SAM, design issues | Development and implementation of guidelines for severe accident management during shutdown conditions and in SFP (SSAMG) | 3.3.8, 3.2.14 | in progress | 2014 |
| 57 | EDU&ETE / PWR | SAM, EP&R | Providing of alternative means for internal and external communication, notification and warning of staff and population during loss of existing infrastructure | 3.3.9, 4.2.7 | in progress | 2013 |
| 58 | EDU&ETE / PWR | SAM | Analysis of habitability MCR/ECR during severe accidents, including the impact on MCR/ECR unaffected unit | 3.3.12 | in progress | 2013 |
| 59 | EDU&ETE / PWR | SAM | Providing of alternative means of abnormal occurrence management during loss of primary control centres (Emergency Control Centre, Physical Protection Control Centre, Fire Protection Control Centre) | 3.3.13 | in progress | 2014 - analysis |
| 60 | EDU&ETE / PWR | SAM | Providing of necessary technical means, protection of personnel and equipment and background during the period outside the implementation of interventions (24 hours / 7 days) | 3.3.14, 3.3.4.4 | in progress | 2013 |
| 61 | EDU&ETE / PWR | SAM | Analyzing of conditions and severe accident scenarios based on the current "state of art", and the results of experiments to conduct research materials during severe accident | 3.3.16 | in progress | constantly |
| 62 | national | national organisations | Reviewing of legislation in the field of nuclear energy – Atomic Act and related decrees – which solve a change of status and role of the regulator | 4.1.1, 4.1.2, 3.3.1, 4.3.6 | in progress | 2015 |
| 63 | national | national organisations cross-cutting issues | Providing of transparency and open communication with the public/stakeholders | 4.1.5, 5.1 | in progress | constantly |

| | | | | | | |
|-----------|----------|--|---|---|-------------|---------------|
| 64 | national | national organisations cross-cutting issues | Consolidation of safety culture – regular assessment of safety culture by regulatory body | 4.1.7, 5.3 | in progress | |
| 65 | national | cross-cutting issues | Setting up open and professional relationship with the regulatory bodies – the realization of regular summits of SUJB with the operator | 5.2 | in progress | |
| 66 | national | national organisation, EP&R | Regular update of Emergency plans | 4.1.4, 4.2.1, 4.2.2, 4.2.4, 4.2.5, 4.2.6 | in progress | |
| 67 | national | International Cooperation | International cooperation – participation of experts of the Czech republic (Regulatory body and operator) in international programs and activities IAEA, OECD/NEA, WANO, EC-ENSREG, WENRA and bilateral cooperation | 4.3.1, 4.3.2, 4.3.3, 4.3.4, 4.3.5 | in progress | |
| 68 | national | SAM | Analyses of potential accident scenarios resulting in large volumes of contaminated water including definition of remedial measures | 3.3.11 | | 2015 |
| 69 | national | SAM | Upgrade PSA LEVEL 2 for both NPPs for the identification of plant vulnerabilities, quantification of potential releases related to extreme external conditions | 3.3.15 | In progress | |
| 70 | national | Natural hazard | Seismic PSA including analysis of secondary effects with a proposals for remedial measures | 3.1.3 | | 2015 |
| 71 | national | national organisations | IRRS missions invited for November 2013 | 4.1.3 | | November 2013 |
| 72 | national | national organisations | Post- Fukushima safety reassessments and action plans – stress tests and follow up action plan | 4.1.6 | In progress | |

| | | | | | | |
|-----------|-----------------|---------------|---|--------|---------------------------|---|
| 73 | ETE/PWR | design issues | Analysis for the SG gravity feeding use in EOPs is to be finished and subsequently EOPs are to be updated | 3.2.1, | In progress | 2014 |
| 74 | EDU, ETE/PWR | design issues | Analyzing of off-site power connections reinforcement. Subsequent reinforcements, if necessary | 3.2.2 | Analyses initiated | analysis 2013, modifications (if needed) 2015 |
| 75 | EDU, ETE/PWR | design issues | Performing batteries capacity real load test | 3.2.3 | Procedures in preparation | 2015 |
| 76 | EDU, ETE/PWR | design issues | Alternative supply of selected valves from mobile power supply sources | 3.2.12 | Analyses in progress | 2015 |

7. Conclusions

All measures contained in the Action Plan are to be completed by the end of 2015. Any problems that may affect implementation of the Action Plan will be considered case by case between the license holder and regulatory authority. If the measure included in the Action Plan is to perform study or analysis, new measures may be identified based on its results. Action plan will be updated accordingly based on results of these considerations. Based on any new information resulting from still on-going investigations of Fukushima accident new measures may be included in the Action Plan as well. Existing deadlines indicated in the Action Plan are mainly allowed by the fact that many of listed measures both Dukovany NPP and Temelin NPP are already in advanced stage of implementation since they were proposed before the Fukushima events on the basis of Periodic Safety Reports results. For example, in case of Dukovany NPP this applies particularly to the seismic hardening to value of 0.1 g acceleration, which was a result of periodic safety review (PSR) of this plant made in 2009.

The core of measures in the Action Plan were proposed by license holder ČEZ, a.s. and accepted by SÚJB (State Office for Nuclear Safety) as nuclear safety regulatory authority. Both Dukovany NPP and the Temelín NPP developed so called Safety Increasing Program (SIP) based on conclusions of the National Stress Tests Report, lessons learned from EU stress tests peer review exercise and previous periodic safety review findings. This initiative is in line with licensee prime responsibility for safety principle defined in the law. After regulatory review the licensee list was supplemented by measures/actions requested by SÚJB. This Action Plan represents complete set of measures (as of 31st December 2012) to strengthen safety of Czech nuclear power plants in response to the Fukushima nuclear power plant accident. Based on article 17 of the Atomic Act this final version of Action Plan will be transferred to the licensee ČEZ, a.s. via letter of SÚJB Chairperson together with description of procedure that will be applied for regulatory oversight of its implementation. In particular, Action Plan implementation will be monitored through scheduled inspections continuously. If needed, new measures will be included or modification of already existing measures will be done in accordance with principles mentioned in previous paragraph.

Both the Action plan, as well as the conclusions of the interim inspection will be made public on the SÚJB and ČEZ, a.s. websites.

References

- [1]: National Report on „Stress Tests“ of NPP Dukovany and NPP Temelín, Czech Republic, December 2011
- [2]: General Peer Review Report, ENSREG, Luxembourg, April 2012
- [3]: ENREG Country Peer Review, April 2012
- [4]: ENSREG - Follow-up fact finding site visit NPP Temelín, September 2012
- [5]: Extraordinary National Report under the Convention on Nuclear Safety, May 2012
- [6]: Final Summary Report of the 2nd Extraordinary Meeting of the Contracting Parties to the CNS, August 2012

[7]: Compilation of recommendations and suggestions, ENSREG, July 2012